



# Morgan County Fire Department

## 3<sup>rd</sup> Party Peer Review for Fire Protection Systems

In accordance with Section 104.7.2 of the International Fire Code, Morgan County Fire will require a “technical opinion and report” (peer review) of all plans for the installation and/or modification of an automatic fire protection system, installation and/or modification of a fire alarm and detection system and related equipment, fire pumps and related fuel tanks, jockey pumps, controllers and related equipment, installation, modification, or removal from service of a standpipe system, and water flow production rates (flow test).

### Exceptions to required peer reviews:

- 1- Installation of fire hydrants and underground fire protection supply lines
- 2- Pre-engineered kitchen hood suppression systems
- 3- Installation or relocation of less than 10 sprinkler heads
- 4- Installation or relocation of less than 10 alarm/notification systems

The following individuals/companies have been approved by Morgan County Fire as design professionals from whom third party plan reviews will be accepted. In addition to these individuals, any other third-party review professional may be acceptable. Credentials listed below must be submitted and reviewed by Morgan County Fire prior to approval.

### Third Party Examiner Qualification Requirements (Utah):

- 1- Licensed Professional Engineer (PE)
- 2- Licensed Fire Protection Engineer (FPE)
- 3- Bachelor’s Degree or Higher in Fire Protection Engineering
- 4- NICET Level III Certification in the Specific Field of Review

Protection Consultants Inc.  
1199 S. Main St. #101  
Centerville, Utah 84014  
Office: 801-295-6070  
Fax: 801-677-6070  
Email: [bob@pciut.com](mailto:bob@pciut.com)

West Coast Code Consultants, Inc. (WC3)  
908 West Gordon Ave. suite #3  
Layton, Utah 84041  
Mobile 435-904-2891  
Office: 385-237-3722  
Email: [scott@wc-3.com](mailto:scott@wc-3.com)  
Submittals: [permitdeskutah@wc-3.com](mailto:permitdeskutah@wc-3.com)

Craig Blue PE, Inc.  
1971 West 3300 South #A  
West Valley City, Utah 84119  
Office: 801-886-3473  
Email: [craig@cbluepe.com](mailto:craig@cbluepe.com)