

# Bull Shoals wastewater monthly report

## April 2026

- Installed new rotating in lift station #5A
- Installed SCADA on lift stations #13 and #15
- Installed new pump in filter building lift station
- Mirco strainer is completed, scheduling pick up from Iowa
- Replaced level transducer in lift station #13
- Helped street department with fixing mower and backhoe issues
- Filled out and filed CIP with ADEQ
- Filled Quarterly report for COA with ADEQ
- Emptied and cleaned both vacuum dewatering beds.
- Filled both drying beds.
- 25,600 gallons of sludge removed from digester
- Replaced stuck relays in lift station #16
- General daily plant checks and maintenance.
- General facilities housekeeping.
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure.
- Lift station inspections and general maintenance.
- Take four-hour composite samples to send to Arkansas Test Labs.
- Treated 6,600,000 gallons in March.

Michael Salentine

Wastewater Supervisor