

Bull Shoals wastewater monthly report

April 2025

- Generator for lift station #16 was delivered and installed, awaiting Craford Electric for start-up.
- Overflow at manhole on Golf Course Terrace. Filed SSO with ADEQ after 9" rain event.
- Used sewer camera to check for possible blockage on Versailles DR.
- Located sewer connection on C.S Woods Blvd.
- Sealed manhole holes behind house on Pace's Ferry DR.
- Enrolled butthole ed in level 3 wastewater class for June and made hotel arraignments in Lonoke.
- Fixed wash out in road between lift stions 5A and 5.
- Checked manholes on back nine of golf course for I&I.
- Hauled pumps and motors to storage that Jack Tyler Engineering removed from lift station #6.
- Cleaned and filled both drying beds
 - 22,600 gallons of sludge transferred from digestor
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 5,946,000 gallons in March

Michael Salentine

Wastewater Supervisor

