

Bull Shoals wastewater monthly report

December 2025

- Continued meetings with ERG,
- Mountain Home camera truck scheduled to come out and camera sewer line (Interceptor #2 from Johnson Loop to Marilyn Ave) for possible infiltration.
- Drying beds lift station Flygt pump went down, was removed and sent to Jack Tyler for troubleshooting and possible repairs.
- Drained and inspected Clarifier #1, adjusted sludge rake arms and tighten bolts
- Scott propane changed out regulators for propane tank for generator at lift station #16
- Cleared tree limbs from above fence line by the drying beds with John Deere
- Winterized RPZs, drying bed feed lines and polymer mixing valve
- Tree fell on fence at treatment plant taking out power and internet. Scheduled NATCO to bury line so plant doesn't lose SCADA.
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,786,000 gallons in November.

Michael Salentine

Wastewater Supervisor