

Bull Shoals wastewater monthly report

February 2025

- Install new motor for Blower #1
- Retrieved broken cover from bottom of manhole on Thompson Circle
 - Fire department washdown debris in manhole
- 20-yard dumpster of sludge hauled off to landfill
- Fixed PVC inlet valve on drying bed
- Cleaned and filled Drying bed #1
 - 11,300 gallons of sludge transferred from digester
- Fixed water leak in filter building
- Uncovered manhole on Interceptor #8 added riser, marked with T post
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
 - Started behind bed & breakfast on Rivercliff down to back nine of golf course
 - Started behind Connie Café down to golf course
 - Continued down back nine to Lift station #16
 - Behind Flippo's Nursing home down to golf course
 - From Golf Course Terrace up to Thompson Circle
 - From 178 to end of Cardinal Drive
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 5,935,000 gallons in January

Michael Salentine

Wastewater Supervisor