

Bull Shoals wastewater monthly report

July 2026

- Installed repaired scum scrapper arm and filled clarifier #2
- Replaced broken filter panels in disc filter
- Took sewer Ford F350 to Schroder's to fix driver side rear inside dually tire
- Call out to end of Atwater for sewer odor, sealed around manhole cover with tar
- Check to see if house on Atwater is connected to sewer or septic. Investigate old septic on property, informed that it must be crushed and filled
- Used old sewer camera
 - to check if pipe going across brown's Beach to see if it is causing road sinkage
 - Brown's Beach and Walden to check for infiltration
- Continued zoom meeting with ERG and ACOMM to find grant money to fix sewer infiltrating.
- General daily plant checks and maintenance.
- General facilities housekeeping.
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure.
- Lift station inspections and general maintenance.
- Take four-hour composite samples to send to Arkansas Test Labs.
- Treated 5,972,000 gallons in June.

Michael Salentine

Wastewater Supervisor