

Bull Shoals wastewater monthly report

January 2025

- Motor for Blower #1 went to West Plains to fix internal short
- Used sewer tracing dye to determine a house on Edgewood Drive was on city sewer or an old septic.
- Filled SSO report for overflow of manhole on Golf Course Terrace to ADEQ
- Dug up sewer tap to check if properly sealed.
- Ordered new motor for Blower #1, rebuild failed
- Cleaned and filled Drying bed #2.
 - 11,600 gallons of sludge transferred from digester.
- Entergy finish line work for lift station #6.
 - Waiting on Jack Tyler to install new pumps.
- Finish biannual oil changes on all lift stations
- Thawed Bypass pump at Lift station #6
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 7,819,000 gallons in December
- Treated 66,728,000 gallons for the year of 2024

Michael Salentine

Wastewater Supervisor