

Bull Shoals wastewater monthly report

July 2025

- Continued meetings with ERG,
- Assisted with cleaning sensors and installing antennae extension on flow meters
- ARWA smoked test sewer mains for the city, we found
 - 19 clean outs with no lids or broken lids
 - 3 faulty service lines
 - 2 broken manholes
- Fixed sewer force main break at lift station #10
 - Fill SSO with ADEQ
- Installed new rotating unit in Lift station #2
- Contacted Primex tech support to get the sewer plant SCADA back online after switching to Natco internet.
- Attended budget meeting for the preliminary 2026 budget
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 7,492,000 gallons in June.

Michael Salentine

Wastewater Supervisor