

Bull Shoals wastewater monthly report

March 2025

- Replaced elbow of air lift system for scum ramp clarifier #2
- Fixed piping issue going to digester
- Fixed broken piping on micro strainer washdown
- Meet with Halff Engineering about possible grant money to fix failing infrastructure
- Cleaned up trees and storm debris from storms
- Replaced front brakes and passenger side rotor of Dodge 2500
- Changed oil and fuel filters on the Ford F350
- Took dodge 2500 to have back glass replaced due to storm damage
- Jack Tyler finished install of pumps on lift station #6 and hauled off their bypass pump
- Entergy will start generator install this month for lift station #16
- Attended meeting with eastern research group about grant money to fix infrastructure
- 20-yard dumpster of sludge hauled off to landfill
- Cleaned and filled both drying beds
 - 22,600 gallons of sludge transferred from digester
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 6,778,000 gallons in February

Michael Salentine

Wastewater Supervisor

