

Bull Shoals wastewater monthly report

September 2025

- Continued meetings with ERG,
- Replaced batteries in three flow monitors
- Helped water department on several water leaks
- Prepped microscreen to be shipped by cleaning out microscreen by running ice through, disconnected electrical and the power washed thoroughly.
- Filled both drying beds
- Sewer locate on Sandot Drive
- Camera sewer line on Carolyn Drive
- Sent influent sample to lab for BOD/TSS removal %
- Scheduled Jack Tyler for warranty work on lift station #6
- Installed new sump pump in lift station #16 basement for drainage.
- Cleaned flow monitors sensors in manholes once a week.
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 5,257,000 gallons in August.

Michael Salentine

Wastewater Supervisor