



Southwater Municipal Utility Authority

St. Clair County-Algonac
WWTP Improvements
Preliminary Design Report

Project No. 241369
August 21, 2026

St. Clair County-Algonac WWTP Improvements Preliminary Design Report

Prepared For:
Southwater Municipal Utility Authority
St. Clair County, Michigan

August 21, 2026
Project No. 241369

1.0	Introduction	1
1.1	Overview	1
1.2	Purpose	1
2.0	Background	1
2.1	Sanitary Sources	1
2.2	Collection System	2
2.3	WWTP Overview	2
2.3.1	Process Flow	2
2.3.2	Solids Flow	3
3.0	WWTP Flows and Loads	3
3.1	NPDES Permit	3
3.2	Flow Rates	3
3.3	Influent Conditions	4
3.4	Effluent Quality and Treatment Performance	5
3.5	Biosolids Handling	5
3.5.1	Digester Loading	5
3.5.2	Digester Treatment Capacity	6
4.0	Proposed Retention System	6
4.1	Overview	6
4.2	Basis of Design	6
4.3	Proposed Location	6
4.3.1	Property Acquisition	6
4.3.2	Environmental Assessment	6
4.4	System Concept	7
4.4.1	Site Layout	7
4.4.2	Design Considerations	7
4.4.3	Control Functional Intent	8
5.0	Treatment Process Improvements	8
5.1	Flow Metering	8
5.1.1	Clay-Ira Meter	8
5.1.2	Algonac Meter	8
5.1.3	WWTP Influent Flow Meter	8
5.1.4	WWTP Effluent Flow Meter	8
5.2	Primary Clarification System	9
5.2.1	Existing Conditions	9
5.2.2	Proposed Improvements	9
5.2.3	Design Considerations	9
5.2.4	Basis of Design	9
5.3	Secondary Clarification System	10
5.3.1	Existing Conditions	10
5.3.2	Proposed Improvements	10
5.3.3	Design Considerations	10
5.3.4	Basis of Design	11
5.3.5	Control Functional Intent	11

5.4	Ferric Chloride System	11
5.4.1	Existing Conditions.....	11
5.4.2	Proposed Improvements	11
5.4.3	Design Considerations	11
5.4.4	Basis of Design	11
5.5	Polymer System	12
5.5.1	Existing Conditions.....	12
5.5.2	Proposed Improvements	12
5.5.3	Design Considerations	12
6.0	Digester System Improvements.....	12
6.1	System Overview	12
6.2	Digester Mixing.....	13
6.2.1	Existing Conditions.....	13
6.2.2	Equipment Options for Proposed Improvements.....	13
6.2.2.1	Recirculated Compressed Gas Mixing	13
6.2.2.2	Liquid Mixing	13
6.2.3	Design Considerations	13
6.3	Gas Handling System	14
6.3.1	Existing Conditions.....	14
6.3.2	Proposed Improvements	14
6.3.3	Design Considerations	14
6.4	Digester Heating	14
6.4.1	Existing Conditions.....	14
6.4.2	Proposed Improvements	14
6.4.3	Design Considerations	15
6.4.4	Basis of Design	15
6.5	Transferring Solids	15
6.5.1	Existing Conditions.....	15
6.5.2	Proposed Improvements	16
6.5.3	Design Considerations	16
6.6	Digester Building.....	16
6.6.1	Existing Conditions.....	16
6.6.2	Proposed Improvements	16
6.6.3	Design Considerations	16
7.0	Electrical, Instrumentation, and Control Systems.....	16
7.1	Power Distribution	16
7.1.1	Overview.....	16
7.1.2	Existing Conditions.....	17
7.1.3	Proposed Improvements	17
7.1.4	Design Considerations	17
7.2	Controls System	17
7.2.1	Existing Conditions.....	17
7.2.2	Proposed Improvements	17
8.0	Discipline-Specific Design Criteria	18
8.1	Process.....	18

8.2	Electrical	18
8.2.1	Codes	18
8.2.2	Hazardous Locations	18
8.3	Mechanical and Plumbing	18
8.4	Structural	19
9.0	Opinion of Probable Cost	19

List of Tables

Table 1 – Effluent Flow Rates – 2022–2026	3
Table 2 – Influent Data – 2022–2026	4
Table 3 – Influent Concentrations by Year – 2022–2025	4
Table 4 – Influent Loads by Year – 2022–2025	4
Table 5 – Effluent Data and Removal Rates – 2022–2026	5
Table 6 – Primary Treatment Removal Rates – 2022–2026	5
Table 7 – Digester Feed Rate – 2023–2025	6
Table 8 – Opinion of Probable Cost	19

List of Appendices

Appendix 1 – Preliminary Civil Design Sheets
Appendix 2 – Preliminary Process Design Sheets
Appendix 3 – Preliminary Electrical Design Sheets

List of Abbreviations/Acronyms

ASME	American Society of Mechanical Engineers
CBOD ₅	5-day carbonaceous biochemical oxygen demand
DP	distribution panel
EGLE	Michigan Department of Environment, Great Lakes, and Energy
ESA	Environmental Site Assessment
gpd	gallons per day
gpm	gallons per minute
lbs	pounds
lbs/d	pounds per day
MBTU/hr	thousand British thermal units per hour
MCC	motor control center
MGD	million gallons per day
mg/L	milligrams per liter
NFPA	National Fire Protection Association
NH ₃ -N	ammonia
NPEDS	National Pollutant Discharge Elimination System
P&ID	process and instrumentation diagram
SMUA	Southwater Municipal Utility Authority
TP	total phosphorus
TSS	total suspended solids
µg/kg	micrograms per kilogram
WWTP	Wastewater Treatment Plant

1.0 Introduction

1.1 Overview

The Southwater Municipal Utility Authority (SMUA) serves the City of Algonac, Clay Township, and Ira Township, and owns and operates the St. Clair County-Algonac Wastewater Treatment Plant (WWTP). Based on Fishbeck's 2026 condition assessment report, SMUA is planning a significant improvements project for the WWTP, including:

1. Addition of a new wet weather retention system.
2. Replacement of two customer flow meters, the raw sewage flow meter, and the effluent flow meter.
3. Replacement of the four primary clarifier tank internal mechanisms and the system controls.
4. Replacement of the two secondary clarifier tank internal mechanisms, drive units, sludge flow meter, and system controls.
5. Replacement of three ferric chloride transfer pumps and tank level instruments.
6. Replacement of the polymer activation and feed system.
7. Replacement of select digester gas handling equipment, one of the digester boiler and heat exchanger units, two digester tank mixing systems, one digester transfer pump, and system controls.
8. Replacement of the power distribution system's main transformer and the main motor control center.
9. Replacement of various process control panels.

An overall site map identifying locations of the proposed improvements is provided in Appendix 1 (see Sheet C201).

SMUA is budgeting \$16,000,000 for completion of the improvements. SMUA is soliciting a federal Community Project Funding grant, requesting \$2,850,000 for the proposed retention system, including a diversion chamber, pump station, two retention tanks, return valve vault, and controls. This federal funding is awaiting approval and may be approved for an amount less than requested. The customer communities plan to self-fund the remaining amount.

1.2 Purpose

The purpose of this Preliminary Design Report is to establish the design criteria for the project improvements. This effort includes developing a conceptual layout for the proposed retention system, process and instrumentation diagrams (P&IDs) for the various unit processes, an electrical one-line diagram, and replacement equipment options for some of the existing equipment.

2.0 Background

2.1 Sanitary Sources

The WWTP provides treatment for approximately 12,300 people in the City of Algonac, Clay Township, and Ira Township. The WWTP has a permitted design flow of 2.7 million gallons per day (MGD). This hydraulic capacity is contractually allocated by SMUA to the contributing municipalities. The City of Algonac is allocated 30% (0.81 MGD) and has an observed average flow of approximately 0.81 MGD. Clay Township is allocated 35% (0.945 MGD) and has an observed average flow of approximately 0.55 MGD. Ira Township is allocated 35% (0.945 MGD) and has an observed average flow of approximately 0.45 MGD.

The facility currently receives trucked waste from a restaurant on Harsens Island. The restaurant has recently received a permit to install a septic system, so trucking waste to the WWTP will no longer be necessary once the septic system is installed.

2.2 Collection System

SMUA owns and operates the three largest pump stations that collectively serve two or more of the customer communities. Aside from these three stations, each community owns and maintains its respective collection system, including its individual pump stations. Clay and Ira Townships have a shared interceptor and are completing sewer lining projects to help reduce the increased flow response during wet weather events. Algonac is pursuing funding for similar projects.

2.3 WWTP Overview

An overall layout of the existing site is included in Appendix 1 (see Sheet C101).

2.3.1 Process Flow

The WWTP includes the following unit processes:

- Liquid Treatment:
 - Influent screening.
 - Raw sewage pumping.
 - Grit removal.
 - Primary clarification.
 - Intermediate pumping to the trickling filters.
 - Trickling filters for secondary treatment.
 - Secondary clarification.
 - Chlorination and de-chlorination.
 - Ferric chloride feed system for phosphorus removal.
 - Polymer feed system for improved primary settleability.
- Biosolids Treatment:
 - Anaerobic digestion.
 - Biosolids storage.

An overall flow schematic is provided in Appendix 2 (see Sheet P102).

The influent sewers from the contributing communities converge at the WWTP in a 30-inch influent pipe that enters the headworks facility. Influent flow first passes through a mechanical bar screen, which discharges screened materials into a washer compactor. There is a manual coarse bar screen in an adjacent channel to provide screening and protect the influent pumps if the mechanical bar screen is out of service.

Screened flow passes into the raw sewage wet well below. Ferric chloride is fed to this influent wet well. There are four raw sewage pumps in the adjacent dry well, which is located in the Main Control Building. The WWTP influent flow meter is located on the discharge header of the raw sewage pumps.

The raw sewage pumps discharge to the aerated grit tank to remove inorganics. The grit tank is outfitted with a bucket mechanism to scoop and lift out grit, where it is passed through a grit classifier.

De-gritted flow enters the primary influent channel where polymer is added for chemically enhanced primary treatment. The flow then moves to one of four rectangular primary clarifiers. The clarifiers have chain and flight mechanisms, and fiberglass covers for odor control. Secondary sludge is also directed to the primary clarifiers for co-settling.

Primary effluent flows by gravity to the two trickling filter pump station wet wells. Four trickling filter pumps feed the two trickling filters. The bolted steel trickling filter tanks are covered with aluminum domes. Flow is pumped up to a center feed mechanism and trickles down through biological growth on crossflow media. Each trickling filter is equipped with two blowers to provide an updraft through the filter media to aerate the treatment process.

Trickling filter effluent splits between two circular secondary clarifiers. Secondary effluent flows by gravity to the chlorination chamber. Effluent samples are collected at the front of the chamber. Then sodium hypochlorite solution is fed to the chamber, which is mixed by submersible jet pumps for disinfection.

Disinfected effluent passes through the final effluent meter chamber, and flows by gravity through a 30-inch effluent pipe to the permitted outfall location at the St. Clair River. Calcium thiosulfate is fed to the outfall pipe for de-chlorination to meet discharge limits.

2.3.2 Solids Flow

A solids flow schematic is provided in Appendix 2 (see Sheet P103).

Settled sludge from the secondary clarifiers is pumped by the secondary sludge pumps to the primary clarifiers for co-settling. Co-settled sludge is then pumped by the primary sludge pump to one of the two anaerobic digester tanks. The digesters are fitted with floating covers and gas mixing systems. The tanks are heated by two boilers with heat exchangers. Three recirculation pumps circulate digester contents through the heat exchangers and back to the tanks. Digested solids are removed by the digester transfer pump to one of the two biosolids storage tanks, and later hauled for land application as final disposal.

3.0 WWTP Flows and Loads

3.1 NPDES Permit

The WWTP is regulated by National Pollutant Discharge Elimination System (NPDES) Permit No. M0020389. The WWTP is authorized to discharge from Monitoring Point 001A through Outfall 001, which discharges to the St. Clair River. The permit is based on a design flow of 2.7 MGD. The effluent discharge limits and other permit requirements are outlined in the NPDES permit.

The WWTP is designated by the Michigan Department of Environment, Great Lakes, and Energy (EGLE) as a Class B treatment facility based on its design capacity to serve a population between 10,000 and 50,000 people.

3.2 Flow Rates

The WWTP has a permitted design flow of 2.7 MGD based on the current NPDES permit. Record drawings indicate the design peak flow for the plant was previously 6.7 MGD; however, the secondary clarifiers present a bottleneck with a design peak flow of 5.7 MGD based on the current Recommended Standards for Wastewater Facilities known as Ten States Standards, and operators report a hydraulic bottleneck occurs with the effluent piping at approximately 5 to 5.5 MGD.

The WWTP reports effluent flow from the effluent meter chamber to EGLE in its monthly discharge monitoring reports. Influent flow is measured on weekdays at the raw sewage pump discharge header but is not reported.

Table 1 summarizes the daily effluent flow from January 2022 through April 2026.

Table 1 – Effluent Flow Rates – 2022–2026

Year	Annual Average (MGD)	Maximum Day (MGD)
2022	1.71	3.51
2023	1.89	5.90
2024	1.96	5.62
2025	1.66	4.75
2022–2026	1.81	5.90

The 4-year maximum flow in Table 1 may reflect the effective capacity or operation of the raw sewage pumps possibly being limited to 4,000 gallons per minute (gpm), or approximately 5.8 MGD.

3.3 Influent Conditions

Influent samples are collected using a composite sampler prior to screening and grit removal.

Table 2 summarizes data from monthly operating reports covering January 2022 through April 2026. Ammonia (NH₃-N) data was reviewed for January 2024 through April 2026. Treatment loads are calculated in pounds per day (lbs/d) based on daily influent concentrations and corresponding effluent flows.

Table 2 – Influent Data – 2022–2026

Parameter	Average Day		4-Year Maximum	
CBOD ₅	157 mg/L	2,290 lbs/d	360 mg/L	6,990 lbs/d
TSS	173 mg/L	2540 lbs/d	415 mg/L	9,990 lbs/d
NH ₃ -N*	19.7 mg/L	282 lbs/d	33.6 mg/L	567 lbs/d
TP*	3.99 mg/L	55.3 lbs/d	10.4 mg/L	198 lbs/d

*Daily ammonia and weekly phosphorus data was provided starting from 2024.

CBOD₅ 5-day carbonaceous biochemical oxygen demand

mg/L milligrams per liter

TP total phosphorus

TSS total suspended solids

In this case, the maximum load appears to correlate with maximum concentrations. This may be a result of extra decanting from the digesters or similar recycle streams being returned to the head of the plant.

Tables 3 and 4 summarize the influent annual average and maximum day concentrations and loads by year, showing the variability from year to year.

Table 3 – Influent Concentrations by Year – 2022–2025

Parameter	2022	2023	2024	2025
CBOD ₅ – Annual Average	169 mg/L	148 mg/L	148 mg/L	168 mg/L
CBOD ₅ – Maximum Day	300 mg/L	360 mg/L	253 mg/L	310 mg/L
TSS – Annual Average	183 mg/L	165 mg/L	168 mg/L	181 mg/L
TSS – Maximum Day	415 mg/L	320 mg/L	325 mg/L	343 mg/L
NH ₃ -N – Annual Average	N/A	N/A	17.9 mg/L	21.9 mg/L
NH ₃ -N – Maximum Day	N/A	N/A	31.2 mg/L	33.6 mg/L
TP – Annual Average	N/A	N/A	3.8 mg/L	7.8 mg/L
TP – Maximum Day	N/A	N/A	4.2 mg/L	10.4 mg/L

Table 4 – Influent Loads by Year – 2022–2025

Parameter	2022	2023	2024	2025
CBOD ₅ – Annual Average	2,360 lbs/d	2,250 lbs/d	2,290 lbs/d	2,270 lbs/d
CBOD ₅ – Maximum Day	4,090 lbs/d	5,080 lbs/d	4,900 lbs/d	6,990 lbs/d
TSS – Annual Average	2,570 lbs/d	2,520 lbs/d	2,670 lbs/d	2,490 lbs/d
TSS – Maximum Day	9,750 lbs/d	9,360 lbs/d	7,380 lbs/d	9,990 lbs/d
NH ₃ -N – Annual Average	N/A	N/A	17.9 lbs/d	21.9 lbs/d
NH ₃ -N – Maximum Day	N/A	N/A	31.2 lbs/d	33.6 lbs/d
TP – Annual Average	N/A	N/A	3.8 lbs/d	7.8 lbs/d
TP – Maximum Day	N/A	N/A	4.2 lbs/d	10.4 lbs/d

The peaking factor for the CBOD₅ load ranges from 1.7 to over 3, and for TSS load from 2.8 to over 4. This also may be a result of extra decanting from the digesters or similar intermittent recycle stream loading.

3.4 Effluent Quality and Treatment Performance

Table 5 summarizes performance data from the same monthly operating reports of January 2022 through April 2026. Effluent samples are collected ahead of the chlorination chamber prior to disinfection at the permit-required frequencies. Percent removal rates are calculated based on the difference between the influent and effluent concentrations on a given day. These removal rates represent the treatment performance of the WWTP.

Table 5 – Effluent Data and Removal Rates – 2022–2026

Parameter	Average Effluent Concentration	Average Removal Rate
CBOD ₅	7.3 mg/L	95%
TSS	11.8 mg/L	93%
NH ₃ -N*	0.77 mg/L	96%
TP	0.66 mg/L	83%

*Daily ammonia data was provided starting from 2024.

The WWTP consistently achieves the NPDES permit required 85% removal efficiencies for CBOD₅ and TSS.

While the NPDES permit does not specify an ammonia limit, effluent water quality indicates the WWTP is able to consistently remove ammonia by maintaining nitrification in the trickling filters throughout the year.

Ferric chloride is added to help precipitate phosphorus to achieve the NPDES permit limit of 1 mg/L on a monthly average basis. The WWTP has consistently met the phosphorus effluent requirements during the years reviewed.

The effluent quality data indicates the WWTP is operating well.

Both ferric chloride and polymer are added upstream of the primary clarifiers for chemically enhanced primary treatment. Table 6 illustrates the effectiveness of this enhanced performance compared to typical removal rates in chemically enhanced and conventional primary treatment.

Table 6 – Primary Treatment Removal Rates – 2022–2026

Parameter	WWTP’s Primary Removal Rate	Typical Chemically Enhanced Primary Removal Rate*	Typical Conventional Primary Removal Rate*
CBOD ₅	56%	40%–70%	25%–40%
TSS	43%	60%–90%	50%–70%
TP	67%	70%–90%	5%–10%

*Source: Water Environment Federation’s *Design of Water Resource Recovery Facilities* (Manual of Practice 8)

CBOD₅ and total phosphorus removal rates are within the typical ranges for chemically enhanced primary treatment. The TSS removal rate is relatively low even for conventional primary treatment, but this may be attributed to the higher solids loading rates resulting from co-settling secondary sludge.

3.5 Biosolids Handling

3.5.1 Digester Loading

Co-settled primary and secondary solids are pumped by the primary sludge pump to the two digester tanks. There is no digester feed flow meter; the volume of sludge fed to the digesters is estimated from a primary sludge pump volume displacement counter. The co-settled material from the primary clarifiers is typically about 4% total solids.

Table 7 summarizes the annual average day and maximum day flow by year for 2023 through 2025. It is unclear what source may account for the wide fluctuation in daily flow.

Table 7 – Digester Feed Rate – 2023–2025

Year	Annual Average Day (gpd)	Maximum Day (gpd)
2023	8,200	23,000
2024	7,900	19,900
2025	8,700	18,000
gpd gallons per day		

3.5.2 *Digester Treatment Capacity*

Assuming a 70% volatile solids content of the co-settled sludge and a design loading rate of 100 lbs of volatile suspended solids per day per 1,000 cubic feet, the two digesters have a total design loading capacity of 8,840 lbs per day of total solids, or 26,500 gallons per day at an assumed solids concentration of 4%.

4.0 Proposed Retention System

4.1 Overview

Influent flows can increase significantly during wet weather events, with a peaking factor up to 4 observed between dry weather months and maximum day flow. A wet weather retention system is planned to allow the diversion and storage of peak flow during wet weather. This will continue to allow proper operation of the contributing collection systems and maintain influent flows to the WWTP below adequate treatment capacities.

4.2 Basis of Design

To adequately size the proposed retention system, a flow monitoring study is currently ongoing. Temporary flow meters have been installed in 10 locations throughout the collection system, to characterize the distribution of flows in the service area, along with two rain gauges to measure rain events. This will allow for a sewer hydraulic model to be calibrated to both dry and wet weather flows as they actually occur in the collection system. The calibrated model will be used to assess the current capacity of the WWTP and determine the retention tank volume and pumping capacity required for the 4.1-inch 25-year, 24-hour design storm event as defined by EGLE under the sanitary sewer overflow standard. The model will also be used to verify that flows under this design storm condition can be properly conveyed through the collection system to the WWTP without causing backups.

4.3 Proposed Location

4.3.1 *Property Acquisition*

Given the limited space available on the existing WWTP site, it was recognized early on that additional property would be necessary to build a new wet weather retention system. Throughout 2026, SMUA has been pursuing the purchase of a publicly owned parcel that consists of a portion of the Algonac Department of Public Works property at 453 State Street and is located directly adjacent to the east of the WWTP. Fishbeck provided a boundary survey for the proposed parcel split.

4.3.2 *Environmental Assessment*

Fishbeck completed a Phase I Environmental Site Assessment (ESA) in anticipation of the property purchase. Based on the Phase I assessment findings, a Phase II ESA was recommended and completed.

For the Phase II ESA, soil and groundwater samples were collected from the property. One of seven soil samples exceeded the non-residential limits for a particular type of volatile organic compound: the limit for Isopropylbenzene (Cumene) is 210 µg/kg (microgram per kilogram), where the soil sample was 1,200 µg/kg. Cumene is a constituent of crude oil and refined fuels. Two ground water samples were collected and had various amounts of arsenic, chromium, copper, and lead that exceeded the non-residential cleanup criteria limits.

Based on the sample results and exceedances, a Baseline Environmental Assessment has been completed and will be filed with the State of Michigan to document that SMUA is not liable for the contamination conditions prior to purchase. Filing the Baseline Environmental Assessment will not commit SMUA to any required cleanup efforts; it will only serve to protect SMUA from future liability, should any arise.

The level of contamination found is not severe enough to prohibit the intended use of the property. However, a Documentation of Due Care Compliance Report will be completed to outline measures necessary for given use and construction on the property. For example, any soil excavated and removed from this area during construction will need to go to a Type II landfill.

4.4 System Concept

4.4.1 Site Layout

A conceptual site layout is provided in Appendix 1 (see Sheet C201). Downstream of the manhole where the Clay-Ira and Algonac interceptors converge, a diversion chamber will be constructed on the 30-inch influent sewer with an overflow weir directing excess flow into a new retention pump station. This pump station will consist of a wet well with submersible pumps to lift flow into the retention tanks. Pumping up into the tanks allows the tanks to be constructed above ground and reduces excavation costs when compared to below grade tanks. Being above ground will allow the tanks to empty by gravity to return flow to the WWTP influent sewer and headworks.

The conceptual layout shows two 50-foot diameter circular tanks, to fit with the 80-foot width of the property being purchased allowing for adequate property setbacks and isolation from a water main along the original property line. The final tank volumes and dimensions will be confirmed based on the ongoing flow monitoring study described in Section 4.2.

The tanks will be bolted steel with aluminum covers. A return valve vault with a manual isolation valve for each tank and a common control valve will allow the tanks to drain by gravity at a controlled rate.

4.4.2 Design Considerations

The existing trickling filter system also has above ground bolted steel tanks. Records indicate these tanks were constructed on pile foundations. It is assumed similar foundations will be required for the retention tanks.

A geotechnical assessment will be completed with soil borings on the proposed property. There are currently large piles of asphalt millings that must be moved off the property to allow the borings to be drilled.

The Documentation of Due Care Compliance Report will include considerations for both design and construction of the below grade structures, including the retention pump station and two valve vaults.

Depending on the tank volume required and the allowable tank diameter on the site, the tanks could be up to 50 to 55 feet high at the dome cover apex. This is comparable in height to the abandoned lime silo portion of the Main Control Building. Based on preliminary discussions with the City of Algonac, there are no initial concerns of height restrictions for the tanks.

Based on the future geotechnical evaluation and recommended tank foundations, constructability considerations will need to be reviewed with various site constraints to confirm the largest feasible tank diameters. This may include setbacks from the property lines and the existing water main and hydrant. Relocation of the water main and hydrant may also need to be considered.

Tank material options, including stainless steel, fusion-bonded, and glass-lined, will be considered based on cost and longevity.

4.4.3 Control Functional Intent

The diversion chamber will have an overflow weir set to divert excess flow to the pump station. If hydraulic conditions are not suitable for a passive overflow, a control slide gate may be used. Normal operation must maximize forward flow through the plant.

The pump station will have level-based control for pump on/off.

The return control valve will have modulating control to provide a variable return rate to maintain pumped raw sewage flow at approximately 3,500 gpm (5.0 MGD).

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P104).

5.0 Treatment Process Improvements

5.1 Flow Metering

5.1.1 Clay-Ira Meter

The Clay-Ira Meter Building consists of a below grade dry meter pit. At this building, the influent 30-inch interceptor from Clay and Ira Townships drops through reduced sized closed pipes and passes through 16-inch and 8-inch flow meters in parallel. These are used to meter flows from Clay and Ira Townships. The 16-inch meter needs to be replaced. The 8-inch meter was replaced recently.

Downstream of the meter piping is a weir prior to transitioning back to a 30-inch gravity sewer. Depending on the arrangement of the weir, the meters could potentially be replaced by an H-flume with a level sensor for calculated flow (similar to the more common Parshall flume).

Replacement options will be investigated further during the final design phase.

Various drain and supernatant piping from different WWTP tanks tie into the 30-inch sewer upstream of the meters. Whenever tank draining or supernatant draw-offs occur, the volume should be noted and subtracted from the customers' metered flow.

5.1.2 Algonac Meter

The separate 18-inch influent sewer from Algonac passes through a below-grade chamber with a closed pipe 16-inch partial flow meter prior to combining with the 30-inch interceptor at the WWTP. This meter is currently abandoned and has been stripped for parts. A portable flow meter is currently installed in the 18-inch Algonac sewer at the downstream manhole. The 16-inch meter needs to be replaced.

5.1.3 WWTP Influent Flow Meter

The WWTP influent 16-inch magnetic flow meter is installed on the raw sewage pump discharge header pipe and needs to be replaced.

This flow signal will be used for control of the retention tank return rate and flow pacing of the ferric chloride and polymer dosing.

5.1.4 WWTP Effluent Flow Meter

The WWTP effluent gravity closed pipe 16-inch partial flow meter is located in the effluent meter chamber downstream from the chlorine contact tank and needs to be replaced. The piping is reduced from the main 24-inch effluent sewer.

5.2 Primary Clarification System

5.2.1 Existing Conditions

From the grit tank, flow enters the small primary influent channel where polymer is fed. Two primary influent pipes direct flow from the influent channel, one to Primary Clarifiers 1 through 3, and the other pipe to Primary Clarifier 4 which was installed later. Each clarifier has two influent isolation gate valves, located in the basement pipe gallery of the Main Control Building.

The tanks are rectangular cast-in-place concrete structures with chain and flight internal mechanisms. Each is 14 feet wide and 60 feet long, with an 8.2-foot side wall depth. Each tank has two fiberglass covers for odor control.

Secondary sludge from the secondary clarifiers is also directed to the primary influent channel for co-settling in the primary clarifiers. Co-settled sludge collects in the sludge hopper where it is drawn off by the primary sludge pump via a 6-inch pneumatically actuated plug valve at each tank. The pump and sludge valves are located in the basement pipe gallery of the Main Control Building.

5.2.2 Proposed Improvements

The four primary clarifier tank chain and flight mechanisms will be replaced, including the gears, sprockets, and shafts. The mechanism drives were recently replaced and will be reused. The upper and lower guide rails for the internal mechanisms are in good condition and will be reused if possible. The influent baffles are concrete and assumed to be in good condition. The galvanized effluent weirs and 10-inch galvanized scum troughs will be replaced with non-corrosive material in each tank. The fiberglass tank covers are expected to be reused. The influent gate valves and pneumatically actuated sludge valves will be reused.

The cast-in-place concrete tanks require some minimal repairs. Fishbeck engineers conducted a structural inspection of Primary Clarifier 1 (assumed to be representative of Primary Clarifiers 2 and 3, being the same age) and Primary Clarifier 4 to determine the extent of recommended concrete repairs. The inspection was mostly visual. Areas of concern were identified during the visual inspection and, where accessible, were sounded with a hammer or similar device to determine if any delamination is present below the surface. Similar repair quantities will be assumed for Primary Clarifiers 2 and 3, and their conditions will be confirmed during construction.

Primary system controls will be replaced. The new control panel will incorporate control signals, feedback and alarms related to the tank drives, pneumatic sludge valves, and the primary sludge pump, all of which are existing and will be reused.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P105).

5.2.3 Design Considerations

If the ferric chloride will continue to be fed to the raw sewage wet well, the primary clarifier component materials should be replaced with non-corrosive metals or plastics where possible. This includes changing the effluent weirs and scum trough from galvanized steel to stainless steel or fiberglass.

5.2.4 Basis of Design

Based on Ten States Standards (Recommended Standards for Wastewater Facilities) design guidelines for co-settling of secondary sludge, the rated treatment capacity of the two primary clarifiers would be a total design average flow of 2.4 MGD and a design peak hourly flow of 4.0 MGD. This would be considered undersized for the hydraulic design flows of the WWTP but is compensated for with polymer addition to provide chemically enhanced primary treatment. This is reflected in the current removal rates achieved by the WWTP primary

treatment, which are significantly higher than typical rates achieved by primary clarification alone, as shown previously in Table 6.

5.3 Secondary Clarification System

5.3.1 Existing Conditions

Trickling filter effluent flows by gravity to the secondary splitter box to one of the two secondary clarifiers with influent isolation slide gates. The box includes a slide gate and piping for a future third tank.

The clarifiers are 55-foot diameter circular tanks that have a 15-foot side wall depth and inboard launder troughs that are offset from the outer wall. The launder troughs are galvanized steel with double v-notch fiberglass weirs. The clarifier internal mechanisms include a plow-type sludge arm and single scum skimmer arm.

Settled sludge is pumped from the secondary clarifiers by the two secondary sludge pumps. Each pump is dedicated to one tank but can pump from either with valve adjustments if the other pump is out of service.

The secondary sludge pump discharge flows through a 4-inch magnetic meter and then through a 6-inch force main. The sludge pumps are controlled by a relay and timer-based control panel.

All sludge is wasted; it is typically directed to the primary clarifiers for co-settling. Existing valving allows for secondary sludge to be pumped directly to the anaerobic digesters, but this is not ideal given the typically thin secondary sludge being only 0.5% solids.

5.3.2 Proposed Improvements

Both secondary clarifier internal mechanisms will be replaced, including the associated drives. The inboard launder troughs and associated double v-notch effluent weirs will be replaced. WWTP staff report the trough supports may be in good enough condition to be reused.

The cast-in-place concrete tanks require some minimal repairs. Fishbeck structural engineers conducted a structural inspection of Secondary Clarifier 2. The inspection was mostly visual. Areas of concern are identified during the visual inspection and, where accessible, were sounded with a hammer or similar device to determine if any delamination is present below the surface. Similar repair quantities will be assumed for Secondary Clarifier 1, and its condition will be confirmed during construction.

While the tank is empty, the center support column and steel access bridge will be visually inspected for section loss. It is expected the column and bridge will be reused and repainted. Launder trough supports can be visually inspected at this time as well.

For the secondary sludge system, the 4-inch magnetic flow meter will be replaced along with the sludge pump controls.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P106).

5.3.3 Design Considerations

If the ferric chloride feed location will be changed to the secondary clarifier splitter box, non-corrosive materials, such as painted steel or stainless steel, must be selected for the secondary clarifier internals. Material selection will be determined during final design.

Electrical conduits extend along the bridge and will need to be replaced or reconnected when the bridge is reinstalled.

The secondary sludge flow meter should be sized for both pumps running simultaneously.

5.3.4 Basis of Design

Based on Ten States Standards design guidelines for facilities with trickling filters upstream, the rated capacity of the secondary clarifiers is a design peak hourly flow of 5.7 MGD. This is lower than the peak design flow of the rest of the plant, indicating a need for a third tank. However, the east-west biosolids storage tanks are installed in the location originally intended for a third clarifier, and now there is not readily available space for a third tank outside the 100-year floodplain.

The existing secondary sludge pumps have a design capacity of 150 gpm.

5.3.5 Control Functional Intent

The pumps currently are not alternated, they are run together for a set amount of time. New controls will allow the pump run times to be programmed for a set number of times per day and length of run time.

5.4 Ferric Chloride System

5.4.1 Existing Conditions

Ferric chloride solution is currently fed to the raw sewage wet well to chemically precipitate phosphorus and assist in the chemically enhanced primary treatment. Record drawings and site observations indicate there may be an alternative feed location at the primary effluent chamber. WWTP staff have recently extended feed piping to the secondary splitter box as another alternative feed location but have not changed operations at this time.

The WWTP currently feeds 38% ferric chloride solution. There are two 9,000-gallon fiberglass bulk storage tanks located in the Chemical Building. There are three pneumatic single-diaphragm transfer pumps; only two are currently working. The transfer pumps are used to fill one of the two day tanks located in the Main Control Building chemical room. Each day tank has two feed pumps.

Only one day tank and its associated feed pumps are currently used. WWTP staff plan to consolidate the feed system independently, to eliminate one day tank and its two feed pumps.

5.4.2 Proposed Improvements

The three ferric transfer pumps will be replaced with double-diaphragm style pumps. The bulk storage tanks' level instruments will be replaced with radar sensors.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P109).

5.4.3 Design Considerations

Ferric chloride is corrosive to most metals, including galvanized steel. If ferric chloride will continue to be fed to the raw sewage wet well, equipment materials, including any up to the primary clarifiers, should be replaced with non-corrosive metals or plastics where possible.

Changing the feed location to the secondary treatment may affect the efficacy of the primary treatment as it is currently enhanced chemically by the upstream dosing of ferric chloride and polymer. However, moving from the raw sewage wet well to the primary clarifiers may protect the raw sewage pumps and grit system from corrosion.

5.4.4 Basis of Design

The existing transfer pump capacity has not been confirmed. WWTP staff report that approximately 60 gpd is fed and thus transferred on average, and can range up to 90 gpd. (The dosing rate was recently decreased from 240 gpd.) Based on the WWTP's current phosphorus removal rates and a 38% ferric chloride solution, this range of 60 to 90 gpd equates an iron to phosphorus molar ratio of 1.3 to 2.0, which is relatively close to the ideal 1:1 ratio for dosing near the primary clarification process.

The operators are accustomed to the transfer pump operation taking about 10 minutes and no more than 15 minutes daily. For the typical range of transfer volumes, this equates to a 10 to 15 gpm pump capacity.

5.5 Polymer System

5.5.1 Existing Conditions

Dry polymer is activated with water in small batches throughout the day in a make-down system. Each batch of polymer is transferred using one of two pumps to a 500-gallon feed tank equipped with a mechanical mixer. Polymer is then fed from the feed tank by one of two peristaltic feed pumps to the primary influent channel.

WWTP staff report a typical usage rate of approximately 4 lbs/day of dry polymer. The system is set to make a new batch of polymer solution every 40 to 45 minutes, with about 35 batches per day. Each batch is made with 51.2 grams of polymer and 45 gallons of water, for a concentration of 300 parts per million. There is currently no flow-based adjustment of the feed rate.

5.5.2 Proposed Improvements

The make-down equipment and transfer pumps will be replaced with a skid system. Instead of transfer pumps, the skid will include dosing pumps to feed the polymer solution directly to the primary influent channel.

The 500-gallon feed tank and existing dosing pumps will be kept for backup service.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P109).

5.5.3 Design Considerations

Based on the enhanced removal rates achieved in the primary clarifiers, the current feed rate on a dry basis appears to be an appropriate starting point for system capacity.

Making a more concentrated polymer solution with less water per batch would allow for greater efficiency

Controls will be included to allow for flow-paced dosing.

6.0 Digester System Improvements

6.1 System Overview

There are two digester tanks to treat the co-settled sludge and reduce volatile solids and overall volume prior to land application. The digester tanks are currently operated in series as one primary digester (being heated and mixed) and one secondary digester (with decanting and solids draw-off). Both tanks are equipped for heating and mixing, and can be alternated as the primary digester. Biogas is produced through the biological anaerobic digestion process. The biogas consists primarily of methane and is a beneficial fuel source that is collected and burned in the boilers used to heat the digesters and the digester building.

Each digester is a 45-foot diameter, above ground, cast-in-place concrete tank. The tanks are insulated on the side and fitted with a floating cover. Located on each floating cover is a gas mixing system housed in a small enclosure.

The Digester Building is also cast-in-place concrete at grade, constructed with shared walls between the two tanks. The lower level houses the pump room with the digester transfer pump and three recirculation pumps. The upper level is the boiler room, with two boilers and heat exchangers to heat the digester contents.

6.2 Digester Mixing

6.2.1 Existing Conditions

Each digester tank has a floating cover with a recirculated compressed gas mixing system. The gas mixing system is a relatively simple technology that draws off the biogas from under the cover and compresses it to discharge the gas at six discharge wells around the bottom of each tank, providing coarse bubbles to mix the tank contents. A gas compressor and six gas valves are located in a compressor house atop each floating cover, with controls and motor starters mounted on the side of the housing. The compressor and two of the six valves for Digester 1 were replaced in 2011. The compressor for Digester 2 and all the remaining valves are original to 1978, along with the controls for both digesters.

6.2.2 Equipment Options for Proposed Improvements

6.2.2.1 Recirculated Compressed Gas Mixing

Recirculated compressed gas mixing technology is no longer commonly used. Only one supplier has been confirmed to still provide the equipment, and the equipment price may be cost-prohibitive.

The flow schematic and P&ID in Appendix 2 (Sheet P108) reflects replacement of the system in kind.

6.2.2.2 Liquid Mixing

More common mixing technology now uses liquid mixing of the digester contents. Typical options include draft tube technology and pumped jet-mixing technology.

Draft tube mixing uses a mechanical mixer, either in a center tube or external tube arrangement. In this case, a center tube is not recommended with the existing floating covers. An external tube arrangement may be feasible but would require large piping penetrations through the tank wall to the flow tube.

Jet mixing uses large-volume mixing pumps to circulate the liquid contents to mix the tank via jet nozzles. While the equipment may be the most cost-effective, there would be retrofitting costs. This arrangement requires large piping penetrations through the tank wall. New jet mixing pumps would likely need to be located outside with heated enclosures as there is not room in the Digester Building for additional pumps and piping.

Though jet mixing may entail more complex retrofitting to the tank, it may be less cost-prohibitive than the gas mixing or draft tube system.

6.2.3 Design Considerations

Costs for the various mixing options will be compared for selection during the final design phase.

Any enclosure with gas mixing equipment, i.e., with piped conveyance and compression of digester biogas, is classified as a Class I, Division 1, Group D, hazardous location. Likewise, any mixing motors, disconnects, and control panel located within the digester tank envelope would need to be properly rated for the classified area.

It may be preferable to replace select older equipment pieces at this time and then replace the mixing systems later with the digester covers. A new gas mixing system may impose limitations or complicate replacement of the floating cover later. Likewise, keeping the existing cover may limit technology options without significant retrofitting to the cover.

6.3 Gas Handling System

6.3.1 Existing Conditions

When not being recirculated through the gas mixing system, digester biogas is collected from under each cover and conditioned through the gas handling system for use in the digester heating system. Excess biogas is flared at the waste gas burners. The system consists of two trains, each capable of serving either digester.

Each gas handling train consists of a sediment trap, low pressure check valve, and positive displacement rotary gas meter. The combined gas from both digesters then passes through a common flame-trap assembly ahead of the boilers and waste gas burners.

Many components of the gas handling system are original from 1978 and beyond their expected useful life. The waste gas burners were replaced in 2012 and 2020.

6.3.2 Proposed Improvements

The two sediment traps, one flame-trap assembly, and drip traps throughout will be replaced, along with the small diameter piping that is showing signs of corrosion and deterioration.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P108).

6.3.3 Design Considerations

Due to the digester gas piping in the lower level pump room, the space is classified as a Class I, Division 1, Group D, hazardous location.

If the gas flow meters are a positive displacement type, they should be replaced with a different type that complies with Ten States Standards.

6.4 Digester Heating

6.4.1 Existing Conditions

The digester heating system includes two boilers, one per tank. Boiler 1 is original and has an integral heat exchanger; Boiler 2 was replaced in 2016 and has a separate external heat exchanger. There are also three recirculation pumps used to draw off digestate, pump it through the heat exchangers, and return it to the digesters.

The boilers are a dual fuel type that can run off either digester biogas or natural gas. The boiler exhaust stacks are located on the building roof. Boiler 1 is older and has an integral heat exchanger; Boiler 2 was recently replaced with an exterior heat exchanger that is mounted on the wall. The boilers heat water that circulates through the heat exchangers to transfer heat to the digester sludge. The recirculation pumps draw sludge from the digesters and through the heat exchangers for warming. The sludge then returns to the digesters as a form of partial mixing.

The three recirculation pumps are controlled by two separate boiler control panels: Pumps 1 and 3 are controlled by the control panel associated with Boiler 1.

The digester tanks are insulated to prevent heat loss.

6.4.2 Proposed Improvements

Boiler 1 will be replaced, either in kind with an integral heat exchanger or with an external heat exchanger. A new control panel will be provided for the boiler and the existing recirculation pumps.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P107).

6.4.3 Design Considerations

It is recommended that Boiler 1 be replaced to match its companion unit, which was replaced in 2016 with a stand-alone boiler and a separate heat exchanger. Besides having a consistent equipment arrangement for the operators, an external heat exchanger would allow for easier cleaning of fouling and greater flexibility to use either heat exchanger with either boiler. Units with integral heat exchangers are not common and such equipment may require sole-sourcing. However, space limitations and budget may necessitate an integral unit. Exact dimensions and layout options will be considered during final design.

Sludge pipe penetrations pass through the floor between the recirculation pumps, tanks, and the heat exchanger piping. This poses a limitation on placement and layout of the equipment. Existing Heat Exchanger 2 may need to be temporarily or permanently relocated to get new equipment in.

The existing boiler flue stacks are relatively short, extending approximately 5 to 6 feet above the roof. While they may meet basic clearance requirements, the low height limits dispersion, thereby increasing the potential for flue gas recirculation. Evaluation is recommended, with potential extension of the stacks.

Based on the estimated boiler capacity, the new boiler needs to comply with American Society of Mechanical Engineers (ASME) Controls and Safety Devices for Automatically Fired Boilers (Standard Number CSD-1), including requirements for flame safeguard controls, low-water cutoff protection, and automatic shutdown and safety interlocks.

Combustion air openings will be verified in accordance with applicable codes. Evaluation will confirm adequacy of room volume and combustion air openings or the need for dedicated outside combustion air.

6.4.4 Basis of Design

The existing Boiler 1 has an input capacity of 750 million British thermal units per hour (MBTU/hr). The Digester System O&M Manual indicates this accounted for 375 MBTU/hr output heating capacity for the digester heat, plus additional for building heat.

Boiler 2 has a higher input capacity of 837 MBTU/hr and an output capacity of 670 MBTU/hr. While this is larger than Boiler 1, it is possible that Boiler 2 was upsized when replaced in 2016, based on standard boiler sizes available, to more than adequately cover the peak heating demand.

Current design standards require digester heating to account for a 1.3 factor of safety in case of fouling in the heat exchangers. The resulting calculated output heating demand is approximately 400 MBTU/hr of sludge heating capacity.

6.5 Transferring Solids

6.5.1 Existing Conditions

There is one primary sludge pump used to feed co-settled sludge to the digester tanks. Pumping is currently controlled on a timed basis, not flow basis. There is a passive overflow pipe on each digester, but there is no instrumentation for monitoring overflow.

There is one piston-style plunger pump used to transfer digested biosolids from either digester. The suction and discharge piping for the pump is concealed under the building floor, including the bypass piping around the pump. The pump can discharge to either of the buried biosolids storage tanks.

A position indicator connected to each floating cover provides level indication of each digester. Digester levels are manually monitored when transferring digested sludge to determine the volume of sludge transferred.

6.5.2 Proposed Improvements

The digester transfer pump and control panel will be replaced.

A flow schematic and P&ID are provided in Appendix 2 (see Sheet P107).

6.5.3 Design Considerations

A double-disc diaphragm style pump may be more desirable from a cost and maintenance perspective. Pump dimensions and piping layout will need to be considered during the final design phase.

6.6 Digester Building

6.6.1 Existing Conditions

Per National Fire Protection Association (NFPA) 820, the Digester Building's lower-level pump room is classified as a Class I, Division 1, Group D, hazardous location.

6.6.2 Proposed Improvements

A gas detection system will be added to the pump room with one sensor for the lower explosive limit (that includes methane) and one sensor for hydrogen sulfide gas. RKI Instrument sensors will be considered, to match existing wet well sensors for plant consistency.

6.6.3 Design Considerations

Although the upper-level boiler room is considered unclassified, it is located within the Digester Building, which shares common walls with anaerobic digesters.

Per NFPA 820, evaluation should include:

- The potential for digester biogas migration into the space, e.g., at pipe penetrations and cracks.
- The adequacy of ventilation.
- Consideration of combustible gas detection.

These items address whether digester biogas can enter the space, whether it can accumulate, and whether it can be detected before reaching unsafe levels.

7.0 Electrical, Instrumentation, and Control Systems

7.1 Power Distribution

7.1.1 Overview

The WWTP receives a 13,200-volt, 3-phase, 3-wire underground electrical service from the local utility company, DTE. Power is delivered to outdoor metering equipment that supplies a SMUA-owned 1,000-kilovolt-amp pad-mounted transformer. The transformer steps down the primary power to 480Y/277-volt, 3-phase, 4-wire utilization voltage.

Secondary power is routed underground to a main switchboard. The main switchboard has an integral automatic transfer switch to the 300 kilowatt diesel standby generator. The switchboard and generator are located in the Generator Building.

From the main switchboard, power is distributed to two motor control centers, MCC BD and MCC C1. MCC BD is in the storage garage and MCC C1 is in the Main Control Building.

From MCC BD, power is distributed to MCC FC and Distribution Panel (DP) 4. MCC FC is in the Secondary Sludge Pump House, and DP 4 is in the Digester Building.

From MCC C1, power is distributed to MCC F1, MCC F2, and DP 1, located in the Main Control Building. From DP 1, power is distributed to DP 2 and DP 3. DP 2 is in the Main Control Building, and DP 3 is in the Chemical Building.

One-line diagrams for the WWTP are provided in Appendix 3.

7.1.2 Existing Conditions

The pad-mounted transformer and all the MCCs and DPs are from the original WWTP construction (in 1968) or the 1976 expansion. The switchboard and generator were installed in 2023.

7.1.3 Proposed Improvements

The pad-mounted transformer and main MCC C1 will be replaced. Connectors between the transformer and main switchboard, and between the main switchboard and MCC C1, will be replaced.

One-line diagrams showing the proposed electrical equipment are provided in Appendix 3 (see Sheets E401 and E402). The connected loads reflect existing equipment at this time and will be updated during the final design phase to reflect proposed equipment replacements.

7.1.4 Design Considerations

Sizing for the pad-mounted transformer, MCC C1, and conductors will be confirmed during the final design phase, based on proposed loads to be connected.

MCC C1 includes a 100-amp breaker and 200-amp breaker to feed MCC F1 and MCC F2, respectively. A majority of the loads fed by MCC F1 and MCC F2 are no longer in use. What loads are remaining may be consolidated to one of these two MCCs, or possibly refed directly from the new MCC C1, to free up some of this 300-amp capacity on MCC C1.

7.2 Controls System

7.2.1 Existing Conditions

Control of the wastewater process equipment is generally accomplished with distributed local control panels for each unit process. These control panels vary in age and were generally installed with the corresponding unit process they control. Most control panels use relays, timers, pushbuttons, and pilot lights with only local control at the panel. A couple control panels have programmable logic controllers that are obsolete and no longer supported. Some panels have been replaced either when pump variable frequency drives were replaced or as the panels became inoperable or obsolete.

A new RACO brand monitoring system was installed in 2020 to improve the system's reliability. The RACO system provides remote alarms for critical fault conditions.

7.2.2 Proposed Improvements

Local control panels with programmable logic controllers will be provided by a systems integrator to support the following equipment or processes:

- Main Control Panel (Main-CP): For retention system, raw sewage pumps, influent flow meter, and primary clarifiers and pump.
- Grit Control Panel (Grit-CP): For grit system, including bucket system, classifier, and blowers.

- Secondary Sludge Control Panel (SS-CP): For secondary sludge pumps, secondary sludge flow meter, and effluent flow meter.
- Digester Control Panel (Digester-CP): For digester tank instruments, digester transfer pump, building alarms, and sludge heating equipment including recirculation pumps.

Local control panels will be provided by corresponding equipment suppliers for the following equipment systems:

- Digester Mixing Equipment.
- Polymer System.

8.0 Discipline-Specific Design Criteria

8.1 Process

The process design shall conform to the applicable design recommendations and standards, including:

- Recommended Standards for Wastewater Facilities, 2026 edition; commonly known as Ten States Standards.
- NFPA 820 – Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 2024 edition.

8.2 Electrical

8.2.1 Codes

The electrical design shall conform to the applicable electrical codes, which include:

- NFPA 70 – National Electric Code, 2023 edition.
- NFPA 70E – National Electrical Safety Code, 2023 edition.
- NFPA 820 – Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 2024 edition.
- Michigan Electrical Code.
- Locally adopted codes and amendments.

Where applicable, electrical equipment will be UL listed and approved.

8.2.2 Hazardous Locations

In general, electrical equipment installed in hazardous locations will be approved for use in the respective location. Conduit seal off fittings will be installed in all conduit runs that enter/leave hazardous locations. Instruments and control devices installed in hazardous locations will utilize intrinsically safe circuitry.

If the Main Control Building were constructed today, the current version of NFPA 820 would require the electrical room be rated as a classified (hazardous) location as it has a direct connection through the stairwell to the raw sewage dry well. Since the space was constructed prior to 1990, when the first edition of NFPA 820 was published, NFPA 820 has an exception that permits the space to remain unclassified. Following the exception permitted by NFPA 820, and with a track record of safe operation of the equipment within the electrical room, equipment will be replaced in kind. Installations will not be rated for a classified (hazardous) location, and the space will not be brought up to current NFPA 820 standards, which would require extensive electrical, heating and ventilation, and potentially architectural changes.

8.3 Mechanical and Plumbing

Replacement of the existing dual fuel (natural gas and biogas) boiler in the Digester Building will comply with the following codes:

- Michigan Mechanical Code – 2021 (based on the 2021 International Mechanical Code).
- Michigan Fuel Gas Code – 2015 (based on the 2015 International Fuel Gas Code).

- ASME Boiler and Pressure Vessel Code, Section IV – 2019 (latest adopted edition).
- ASME CSD-1 – 2018 (Controls and Safety Devices for Automatically Fired Boilers).
- NFPA 70 – National Electric Code, 2023 edition.
- NFPA 820, as adopted and enforced by the Authority Having Jurisdiction (i.e., Fire Protection in Wastewater Treatment and Collection Facilities).

8.4 Structural

The structural design shall conform to applicable structural and building codes, which include:

- American Concrete Institute 350 – Code Requirements for Environmental Engineering Concrete Structures, 2020 edition.
- American Concrete Institute 318 – Building Code Requirements for Structural Concrete, 2019 edition.
- Michigan Building Code, 2021 edition.
- American Institute of Steel Construction 360 – Specification for Structural Steel Buildings, 2016 edition.

9.0 Opinion of Probable Cost

The opinion of probable project cost was updated from the 2026 condition assessment report, based on revised project scope and considerations discussed in this report. The improvements included in the proposed project and the associated costs are included in Table 8. Budgets reflect costs for starting construction in 2027. These costs currently include a 30% design contingency. The retention system and digester system costs currently account for higher cost equipment options; lower cost options will be explored during the final design phase.

Table 8 – Opinion of Probable Cost


Item	Budget
New Retention System	\$5,700,000
Flow Metering Improvements	\$410,000
Primary Clarification Improvements	\$1,100,000
Secondary Clarification Improvements	\$1,400,000
Ferric Chloride System Improvements	\$40,000
Polymer System Improvements	\$260,000
Anaerobic Digestion Improvements	\$2,500,000
Electrical Power Distribution Improvements	\$560,000
Process Control Panel Improvements	\$690,000
Construction Subtotal	\$12,660,000
General Conditions, Overhead and Profit	\$2,150,000
Total Construction Cost	\$14,810,000
Design Engineering	\$1,545,000
Construction Engineering and Observation (10%)	\$1,500,000
Total Project Cost	\$17,855,000

Any federal funding received will impose certain construction requirements including domestic material procurement and wage rates. It may be preferable to separate the federally funded portion of the project under a separate contract, possibly a pre-procurement package for the retention tank structures.

Appendix

1

PLOT INFO: Z:\2024\241369\CADD\C101\241369.DWG LAYOUT: C101 DATE: 6/11/2026 TIME: 7:16:34 PM USER: DRHOTON



EXISTING CONDITIONS PLAN
SCALE: 1" = 30'
0 15 30 60

BENCH MARKS

- BENCH MARK 200 ELEVATION: 578.82
CHISELED X ON NORTH SIDE OF RIM OF SANITARY MANHOLE IN DRIVE TO SURVEYED SITE, 300' WEST OF STATE STREET
- BENCH MARK 201 ELEVATION: 579.23
CHISELED X ON SOUTH SIDE OF RIM OF ELECTRIC MANHOLE, 36' EAST OF CONTROL BUILDING AND 53' NORTH OF GENERATOR ROOM
- BENCH MARK 202 ELEVATION: 583.19
CHISELED X ON SOUTH BOLT OF VERTICAL PIPE NEAR SOUTHWEST CORNER OF PRIMARY SETTLING TANKS AND 54' SOUTH OF SLUDGE DIGESTER #2
- BENCH MARK 203 ELEVATION: 579.75
CHISELED X ON WEST SIDE OF RIM OF SANITARY MANHOLE NEAR SOUTHWEST CORNER OF MAINTENANCE GARAGE
- BENCH MARK 204 ELEVATION: 585.27
MAG NAIL IN NORTHEAST CORNER OF CONCRETE FOUNDATION FOR TANK ON NORTHWEST SIDE OF SURVEYED SITE
- BENCH MARK 205 ELEVATION: 577.36
CHISELED X ON EAST SIDE OF RIM OF SANITARY MANHOLE NEAR STAIRS & ELEVATED PLATFORM NORTH OF TRICKLING FILTERS & 92' WEST OF METER PIT BUILDING
- BENCH MARK 206 ELEVATION: 579.52
CHISELED X ON SOUTH BOLT IN BASE OF LIGHT POLE, 40' NORTH OF CHEMICAL BUILDING

SYMBOL LEGEND

- BENCH MARK
- PROPERTY LINE
- SOIL BORING
- CONIFEROUS TREE
- DECIDUOUS TREE
- CONTOUR MAJOR
- CONTOUR MINOR
- LIGHT
- UTILITY POLE
- SIGN
- FENCE LINE
- GRAVEL SURFACE
- PAVED SURFACE
- 8" SAN SANITARY SEWER & MANHOLE
- 12" STM STORM SEWER & MANHOLE
- CATCH BASIN CURB AND LAWN TYPE
- VALVE
- HYDRANT
- 6" WTR WATER MAIN
- 2" GAS GAS MAIN
- METER

SURVEY NOTES

- TOPOGRAPHIC SURVEY WAS COMPLETED BY FISHBEEK IN MARCH 2026 AND REFLECTS CONDITIONS AT THAT TIME. THE SURVEY HAS BEEN SUPPLEMENTED WITH RECORD INFORMATION FOR THE CONTRACTOR'S CONVENIENCE. THE CONTRACTOR IS RESPONSIBLE FOR VISITING THE SITE PRIOR TO BIDDING TO CONFIRM EXISTING CONDITIONS AS SHOWN ON THE PLANS. REPORT ALL DISCREPANCIES TO THE ENGINEER.
- THE HORIZONTAL AND VERTICAL INFORMATION PROVIDED IS BASED ON THE MICHIGAN STATE PLANE COORDINATE SYSTEM (SOUTH ZONE, INTERNATIONAL FEET) WITH NAD83 HORIZONTAL AND NAVD83 VERTICAL DATUM, RESPECTIVELY.
- UNDERGROUND UTILITIES ARE SHOWN BASED ON SURFACE MANHOLE AND VALVE LOCATIONS, RECORD DRAWINGS, AND OWNER PROVIDED UTILITY MAPS AND MAY NOT BE ACCURATE. CONTRACTOR SHALL CONTACT MISS DIG PRIOR TO ANY EXCAVATION. CONTACT ENGINEER IF UTILITIES ARE FOUND IN DIFFERENT CONDITIONS THAN SHOWN ON THESE PLANS.
- PIPE ROUTING IS DIAGRAMMATIC. ALL EQUIPMENT & PIPES ARE TO BE FIELD VERIFIED PRIOR TO CONSTRUCTION.

GEOTECHNICAL NOTES

- GEOTECHNICAL FIELD INVESTIGATION AND REPORT PREPARED BY [GEOTECHNICAL ENGINEER] IN [DATE MM/YYYY] AND REFLECT CONDITIONS AT THAT TIME.
- USCS SOIL CLASSIFICATION: [INSERT TYPICAL SOIL DATA]

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

REVISIONS

NOT FOR CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW

Drawn By DRHOTON
Designer DRHOTON
Reviewer ERANDOLPH
Manager ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.


PROJECT NO.
241369

SHEET NO.

C101

©Copyright 2026
All Rights Reserved

PLOT INFO: Z:\2024\241369\CADD\C201\241369.DWG LAYOUT: C201 DATE: 6/11/2026 TIME: 7:30:38 PM USER: DRHOTON



SITE AND UTILITY PLAN
SCALE: 1" = 30'
0 15 30 60

BENCH MARKS

- BENCH MARK 200 ELEVATION: 578.82
CHISELED X ON NORTH SIDE OF RIM OF SANITARY MANHOLE IN DRIVE TO SURVEYED SITE, 300' WEST OF STATE STREET
- BENCH MARK 201 ELEVATION: 579.23
CHISELED X ON SOUTH SIDE OF RIM OF ELECTRIC MANHOLE, 36' EAST OF CONTROL BUILDING AND 53' NORTH OF GENERATOR ROOM
- BENCH MARK 202 ELEVATION: 583.19
CHISELED X ON SOUTH BOLT OF VERTICAL PIPE NEAR SOUTHWEST CORNER OF PRIMARY SETTLING TANKS AND 54' SOUTH OF SLUDGE DIGESTER #2
- BENCH MARK 203 ELEVATION: 579.75
CHISELED X ON WEST SIDE OF RIM OF SANITARY MANHOLE NEAR SOUTHWEST CORNER OF MAINTENANCE GARAGE
- BENCH MARK 204 ELEVATION: 585.27
MAG NAIL IN NORTHEAST CORNER OF CONCRETE FOUNDATION FOR TANK ON NORTHWEST SIDE OF SURVEYED SITE
- BENCH MARK 205 ELEVATION: 577.36
CHISELED X ON EAST SIDE OF RIM OF SANITARY MANHOLE NEAR STAIRS & ELEVATED PLATFORM NORTH OF TRICKLING FILTERS & 92' WEST OF METER PIT BUILDING
- BENCH MARK 206 ELEVATION: 579.52
CHISELED X ON SOUTH BOLT IN BASE OF LIGHT POLE, 40' NORTH OF CHEMICAL BUILDING

SYMBOL LEGEND

- BM BENCH MARK
--- PROPERTY LINE
725 CONTOUR MAJOR
724 CONTOUR MINOR
- ASPHALT PAVEMENT, SEE DETAIL
MAINTENANCE STRIP
4" THICK CONCRETE SIDEWALK
- EJ EXPANSION JOINT
X FENCE
- 8" SAN SANITARY SEWER & MANHOLE
8" FM FORCE MAIN
M METER
GAS MAIN
ELECTRIC

NOTES

- DIMENSIONS ARE TO BACK OF CURB, OUTSIDE FACE OF BUILDING, AND EDGE OF PAVEMENT UNLESS NOTED OTHERWISE.
- KEEP THE APPROVED AND/OR MOST CURRENT SET OF PROJECT DRAWINGS ON SITE AT ALL TIMES. CONTRACTOR TO CONFIRM THEY ARE IN POSSESSION OF THE MOST CURRENT DRAWING FILES.
- RESTORE ALL DISTURBED AREA WITH SUITABLE TOPSOIL AND SEED.

UTILITY NOTES

- EXISTING UTILITIES LOCATIONS SHOWN ARE APPROXIMATE.
- VERIFY THE HORIZONTAL AND VERTICAL LOCATION OF EXISTING UTILITIES PRIOR TO EXCAVATION WHERE NECESSARY.
- PROTECT AND MAINTAIN SERVICE OF OTHER UTILITIES AT CROSSINGS.
- DO NOT CONNECT ROOF DRAINS, FOUNDATION DRAINS, AND OTHER CLEAN WATER SERVICES TO THE SITE RECYCLE DRAINS.
- PROVIDE AND MAINTAIN INLET FILTERS AT ALL CATCH BASIN INLETS, DURING CONSTRUCTION.
- WATER MAIN AND FORCE MAIN TO HAVE A MINIMUM OF FIVE (5) FEET OF COVER.
- PROVIDE A MINIMUM OF EIGHTEEN (18) INCHES OF VERTICAL SEPARATION AND TEN (10) FEET OF HORIZONTAL SEPARATION BETWEEN THE WATER MAIN AND ALL SANITARY AND STORM SEWERS.
- ADJUST ALL CASTINGS TO FINISH GRADES.
- PIPE LENGTHS ARE TO CENTER OF STRUCTURES UNLESS NOTED OTHERWISE. ALL PIPE LENGTHS ARE FOR THE CONVENIENCE OF THE CONTRACTOR.
- UTILITY ELEVATIONS INDICATED REPRESENT INVERT ELEVATIONS UNLESS OTHERWISE NOTED.

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW
Drawn By	DRHOTON
Designer	DRHOTON
Reviewer	ERANDOLPH
Manager	ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.
241369
SHEET NO.

C201

Appendix

2

GENERAL ABBREVIATIONS

A	AIR	IR	ISOLATION RING
AB	ANCHOR BOLT	JT	JOINT
ABAN	ABANDON, ABANDONED	LAB	LABORATORY
ADJ	ADJACENT	LAT	LATERAL
AFF	ABOVE FINISHED FLOOR	LB	POUND
AG	ABOVE GRADE	LF	LINEAL FOOT
AL	ALUMINUM	LGTH	LENGTH
ALT	ALTERNATE, ALTERNATIVE	LH	LEFT HAND
AMT	AMOUNT	LQ	LIQUID
APPROX	APPROXIMATE	LLWL	LOW LOW WATER LEVEL
ASSY	ASSEMBLY	LONG	LONGITUDINAL
AVG	AVERAGE	LP	LOW POINT
BB	BACK TO BACK	LR	LONG RADIUS
BF	BLIND FLANGE	LWL	LOW WATER LEVEL
BFG	BELOW FINISHED GRADE	M	MOTOR
BFP	BACKFLOW PREVENTER	MAINT	MAINTENANCE
BG	BIOGAS	MATL	MATERIAL
BLDG	BUILDING	MAX	MAXIMUM
BLKHD	BULKHEAD	MEZZ	MEZZANINE
BLWDN	BLOWDOWN	MFR	MANUFACTURER
BM	BENCHMARK	MGD	MILLION GALLONS PER DAY
BMC	BOLTED MECHANICAL COUPLING	MH	MANHOLE
BTM	BOTTOM	MIN	MINIMUM
BRG	BEARING	MISC	MISCELLANEOUS
BSMT	BASEMENT	MJ	MECHANICAL JOINT
BTU	BRITISH THERMAL UNITS	MTD	MOUNTED
BTWN	BETWEEN	MTL	METAL
C/C	CENTER TO CENTER	N/A	NOT APPLICABLE
CF	CUBIC FEET	NIC	NOT IN CONTRACT
CFM	CUBIC FEET PER MINUTE	NO	NUMBER
CFS	CUBIC FEET PER SECOND	NPT	AMERICAN NATIONAL TAPER PIPE THREAD
CHAM	CHAMFER	NTS	NOT TO SCALE
CHEM	CHEMICAL	OC	ON CENTER
CHKPL	CHECKERPLATE	OD	OUTSIDE DIAMETER
CL	CENTERLINE	OPNG	OPENING
CLR	CLEARANCE	OPP	OPPOSITE
CO	CLEANOUT	ORIG	ORIGINAL
COMP	COMPANION	OH	OVERHEAD
COND	CONCRETE	P&ID	PROCESS AND INSTRUMENTATION DIAGRAM
CONC	CONCENTRATED	PE	PLAIN END
CONC	CONCENTRIC	PERF	PERFORATED
CONST	CONSTRUCTION	PHA	PHOSPHORIC ACID
COORD	COORDINATE	PL	PLATE
CPLG	COUPLING	PNL	PANEL
CTL	CONTROL	PPM	PARTS PER MILLION
CW	COLD WATER	PROP	PROPOSED
CY	CUBIC YARD	PS	PUMP STATION
DEG	DEGREE	PSF	POUNDS PER SQUARE FOOT
DEMO	DEMOLITION	PSI	POUNDS PER SQUARE INCH
DET	DETAIL	Q	FLOW
DIA	DIAMETER	QD	QUICK DISCONNECT
DIF	DIFFUSER	QTY	QUANTITY
DIM	DIMENSION	R	RADIUS
DIR	DIRECTION	RD	ROOF DRAIN
DISCH	DISCHARGE	RECIRC	RECIRCULATE, RECIRCULATING, RECIRCULATION
DIST	DISTANCE	RED	REDUCER, REDUCING
DMS	DIAPHRAGM SEAL	REF	REFERENCE
DN	DOWN	REHAB	REHABILITATION
DP	DEEP, DEPTH	REINF	REINFORCE, REINFORCING
DWG	DRAWING	REQD	REQUIRED
DWV	DRAIN WASTE VENT	REV	REVISION
EA	END TO END	RFA	RESTRAINED FLANGE ADAPTER
EAC	EACH	RH	RIGHT HAND
ECC	ECCENTRIC	RJ	RESTRAINED JOINT
EHT	ELECTRICALLY HEAT-TRACED	RM	ROOM
EJ	EXPANSION JOINT	RO	ROUGH OPENING
EL ELEV	ELEVATION	RPM	REVOLUTIONS PER MINUTE
EL	ELBOW	RSR	RISER
EMBED	EMBEDMENT	RUB	RUBBER
ENGR	ENGINEER	SAN	SANITARY
EQ	EQUAL	SCH	SCHEDULE
EQUIP	EQUIPMENT	SCRN	SCREEN
ES	EACH SIDE	SED	SEDIMENTATION
ESEW	EMERGENCY SHOWER AND EYE WASH	SHT	SHEET, SHEETING
EW	EACH WAY	SH	SIMILAR
EX, EXIST	EXISTING	SL	SLOPE
EXC	EXCAVATE, EXCAVATION	SP	SAMPLE POINT
EXP	EXPOSED	SP	STATIC PRESSURE
EXT	EXTERIOR	SPEC	SPECIFICATION/SPECIFIED
FF	FACE TO FACE	SPR	SPARE
FAB	FABRICATED	SF	SQUARE FOOT
FD	FLOOR DRAIN	SY	SQUARE YARD
FF	FINISHED FLOOR	SR	SHORT RADIUS
FIG	FIGURE	SS	STAINLESS STEEL
FIN	FINISHED	STA	STATION
FLR	FLOOR	STD	STANDARD
FM	FORCE MAIN	STG	STORAGE
FRP	FIBERGLASS REINFORCED PLASTIC	STL	STEEL
FSP	FABRICATED STEEL PIPE	SUBM	SUBMERGED
FTG	FITTING	SUCT	SUCTION
FV	FIELD VERIFY	SURF	SURFACE
GA	GAUGE/GAGE	SUSP	SUSPENDED
GAC	GRANULATED ACTIVATED CARBON	SW	SOCKET WELDED
GFA	GROOVED FLANGE ADAPTER	SYS	SYSTEM
GPC	GROOVED PIPE COUPLING	TDH	TOTAL DYNAMIC HEAD
GPD	GALLONS PER DAY	TEMP	TEMPERATURE
GPM	GALLONS PER MINUTE	THK	THICK
GR	GRADE	TYP	TYPICAL
HB	HOSE BIBB	UG	UNDERGROUND
HDPE	HIGH DENSITY POLYETHYLENE EXTRUSION	UL	UNDERWRITERS LABORATORY
HDWL	HEADWALL	UNO	UNLESS NOTED OTHERWISE
HGL	HYDRAULIC GRADE LINE	UTIL	UTILITY
HGR	HANGER	UV	ULTRAVIOLET LIGHT
HWL	HIGH HIGH WATER LEVEL	V	VOLTS
HORIZ	HORIZONTAL	VAC	VACUUM
HP	HIGH POINT	VB	VALVE BOX
HP	HORSEPOWER	VERT	VERTICAL
HT	HEIGHT	VOL	VOLUME
HVAC	HEATING, VENTILATING AND AIR CONDITIONING	VTR	VENT THROUGH ROOF
HW	HOT WATER	VTW	VENT THROUGH WALL
HWL	HIGH WATER LEVEL	W/	WITH
HYD	HYDRAULIC	W/O	WITHOUT
HZ	HERTZ	WT	WEIGHT
ID	INSIDE DIAMETER	WH	WALL HYDRANT
IE	INVERT ELEVATION	WL	WATER LEVEL
IN	INCH	WP	WEATHERPROOF
INCL	INCLUDE	WS	WATERSTOP
INSUL	INSULATE, INSULATION	WSE	WATER SURFACE ELEVATION
INSTR	INSTRUMENT, INSTRUMENTATION	WT	WATERTIGHT
INT	INTERIOR	XP	EXPLOSION PROOF
INV	INVERT		
IPS	IRON PIPE SIZE		

PIPE/TUBING MATERIAL ABBREVIATIONS

CI	CAST IRON
CPVC	CHLORINATED POLYVINYL CHLORIDE
CS	CARBON STEEL
CU	COPPER
DI	DUCTILE IRON
FRP	FIBERGLASS REINFORCED PLASTIC
GALV	GALVANIZED STEEL
HDPE	HIGH-DENSITY POLYETHYLENE
LCS	LINED CARBON STEEL
LDI	LINED DUCTILE IRON
PCCP	PRESTRESSED CONCRETE CYLINDER PIPE
PE	POLYETHYLENE
PP	POLYPROPYLENE
PTFE	TEFLON PIPE
PVC	POLYVINYL CHLORIDE
PVDF	POLYVINYLIDENE FLUORIDE (KYNAR)
RCP	REINFORCED CONCRETE PIPE
###SS	STAINLESS STEEL (### INDICATES GRADE)
TT	TITANIUM

EQUIPMENT TYPE ABBREVIATIONS

A	AIR SYSTEM
AIC	AIR COMPRESSOR
BFP	BELT FILTER PRESS
BP	BOOSTER PUMP
BPS	BOOSTER PUMP SKID
BTk	BULK STORAGE CHEMICAL TANK
B	BLOWER
CENT	CENTRIFUGE
CF	CARTRIDGE FILTER
CL	CLEAN-IN-PLACE
CL	CLARIFIER
CN	CONVEYOR
DIF	DIFFUSER
DIG	DIGESTER
DTK	DAY TANK (CHEMICAL)
ESEW	EMERGENCY SHOWER AND EYE WASH
FLT	FILTER
FM	FLOCCULATOR MIXER
GT	GRAVITY THICKENER
HP	HIGH-PRESSURE PUMP
HSP	HIGH SERVICE PUMP
HTR	HEATER
HX	HEAT EXCHANGER
LSP	LOW SERVICE PUMP
MH	MANHOLE
MX	MIXER
PUMP	PUMP
PF	PLATE AND FRAME FILTER PRESS
PM	POLYMER FEED SYSTEM
R	REACTOR
RD	RUPTURE DISC
RPZ	REDUCED PRESSURE ZONE VALVE
S	SAMPLER
SCP	SCREW PRESS
SCR	SCREEN
SMP	SUMP PUMP
SP	SAMPLE PUMP
STR	STRAINER
T	TANK
TP	TRANSFER PUMP
U	MISCELLANEOUS EQUIPMENT
UV	ULTRAVIOLET DISINFECTION
WC	WASHER COMPACTOR

VALVE ABBREVIATIONS

ANV	ANGLE VALVE
ARV	AIR RELEASE VALVE
AVV	AIR/VACUUM VALVE
BAV	BALL VALVE
BFV	BUTTERFLY VALVE
BPV	BACKPRESSURE VALVE
CAV	COMBINATION AIR/VACUUM RELEASE VALVE
CKV	CHECK VALVE
CNV	ROTARY CONE VALVE
CV	CONTROL VALVE
DV	DIAPHRAGM VALVE
ECV	ELECTRONIC CONTROL VALVE
EPV	ECCENTRIC PLUG VALVE
GBV	GLOBE VALVE
GV	GATE VALVE
HG	HAND GATE
MDV	MUD VALVE
NV	NEEDLE VALVE
PRV	PRESSURE RELIEF VALVE
PNV	PINCH VALVE
PRV	PRESSURE REDUCING VALVE
PSV	PRESSURE SUSTAINING/RELIEF VALVE
PV	PLUG VALVE
SAV	SURGE ANTICIPATOR VALVE
SG	SLIDE OR SLUICE GATE
SL	STOP LOG
SV	SOLENOID VALVE
TSV	THERMAL OPERATED SHUT-OFF VALVE
V	VALVE
VBV	VACUUM BREAKER VALVE
VG	WEIR GATE
XV	SPECIALTY VALVE

PIPE SYSTEM ABBREVIATIONS

ALUM	ALUMINUM SULFATE
AR	AIR RELEASE (RELIEF)
AS	AIR SCOUR
BG	BIOGAS
BWR	BACKWASH RETURN
BWS	BACKWASH SUPPLY
BWW	BACKWASH WASTE
CA	COMPRESSED AIR
CIT	CITRIC ACID
CLP	CHLORINE GAS (PRESSURIZED)
CLS	CHLORINE SOLUTION
CN	CENTRATE
DC	DECANT
DG	DIGESTER GAS
DR	DRAIN
DSL	DIGESTED SLUDGE
DW	DILUTION WATER
EQ	EQUALIZED WASTEWATER
FE	FINAL EFFLUENT
FECL	FERRIC CHLORIDE / FERROUS CHLORIDE
FLT	FILTRATE
FTW	FILTER TO WASTE
FW	FILTERED WATER
GRIT	GRIT SLURRY
HFS	HYDROFLUOROSILICIC ACID
HYPO	SODIUM HYPOCHLORITE
IA	INSTRUMENT AIR
LIME	LIME
LO	LUBRICATION OIL
LPA	LOW PRESSURE AIR
LQ	LIQUEFIED PETROLEUM GAS
ME	METHANOL
ML	MIXED LIQUOR
NAOH	SODIUM HYDROXIDE (CAUSTIC)
NATRG	NATURAL GAS
NH	AMMONIA
O2	OXYGEN
O3	OZONE
OF	OVERFLOW
PA	PLANT AIR
PAC	POWDERED ACTIVATED CARBON
PAL	POLYALUMINUM CHLORIDE
PE	PRIMARY EFFLUENT
PEW	PLANT EFFLUENT WATER
PH	PHOSPHATE
PI	PRIMARY INFLUENT
PIPR	PRIMARY INFLUENT W/ PLANT RECYCLE
POLY	POLYMER
PP	POTASSIUM PERMANGANATE
PR	PLANT RECYCLE
PSW	PLANT SERVICE WATER
PW	POTABLE/FINISHED WATER
RAS	RETURN ACTIVATED SLUDGE
RAW	RAW WATER
SA	SULFURIC ACID
SAN	SANITARY
SBS	SODIUM BISULFITE
SCUM	SCUM
SCE	SECONDARY CLARIFIER EFFLUENT
SE	SECONDARY EFFLUENT
SL	SLUDGE
SLR	SLUDGE RECIRCULATION
SN	SUPERNATANT
SODA	SODA ASH
SPD	SUMP PUMP DISCHARGE
SPL	SAMPLE LINE
SSL	SECONDARY SLUDGE
STR	SLUDGE TRANSFER
STW	SETTLED/CLARIFIED WATER
TE	TERTIARY EFFLUENT
TSL	THICKENED SLUDGE
V	VENT
VC	VACUUM
WAS	WASTE ACTIVATED SLUDGE
WF	WARM FLARE
WW	INFLUENT WASTEWATER (RAW)

ANALYTICAL ABBREVIATIONS

ALK	ALKALINITY
CH4	METHANE
CL2	CHLORINE
COMB	COMBUSTIBLE GAS
CON	CONDUCTIVITY
DO	DISSOLVED OXYGEN
F	FLUORIDE
IR	INFRARED
H2S	HYDROGEN SULFIDE
METH	METHANOL
NH3	AMMONIA
NO3	NITRATE
O2	OXYGEN
O3	OZONE
ORP	OXIDATION/REDUCTION POTENTIAL
PC	PARTICLE COUNTER
PH	HYDROGEN ION CONCENTRATION
P04	PHOSPHATE
SC	STREAMING CURRENT
SO2	SULFUR DIOXIDE
TH	TOTAL HARDNESS
TSS	TOTAL SUSPENDED SOLIDS
TURB	TURBIDITY
UV	ULTRAVIOLET

GENERAL SHEET NOTES

- THIS IS A STANDARD LEGEND SHEET. THEREFORE, NOT ALL OF THE INFORMATION SHOWN MAY BE USED ON THIS PROJECT.
- CONTACT ENGINEER FOR ABBREVIATIONS USED BUT NOT SHOWN ON THIS DRAWING.

PROCESS GENERAL NOTES

- THE FOLLOWING NOTES APPLY TO ALL PROCESS SHEETS.
- NOTES, SYMBOLS, LEGENDS, AND ABBREVIATIONS SHOWN ON PROCESS DRAWINGS MAY NOT BE ALL INCLUSIVE. ONLY APPLY TO PROCESS DRAWINGS (P### SHEETS) AND, WHEN PRESENT, PROCESS DEMOLITION (D4## SHEETS).
- GRAPHICAL REPRESENTATION OF EXISTING SYSTEMS IS BASED ON PREVIOUS CONSTRUCTION AND/OR RECORD DRAWINGS AND MAY NOT FULLY REPRESENT EXISTING CONDITIONS, AND IS FOR REFERENCE ONLY. FIELD VERIFY EXISTING CONDITIONS TO DETERMINE EXTENT OF WORK.
- FIELD VERIFY ALL DIMENSIONS SHOWN.
- REFER TO PIPING PLAN VIEWS FOR CORRECT PIPE ORIENTATION TO BUILDINGS AND STRUCTURES.
- SEE STRUCTURAL FOR TYPICAL EQUIPMENT PAD DETAIL FOR NEW EQUIPMENT INSTALLATION.
- WALL SLEEVES AND WALL PIPE TO BE PAINTED PRIOR TO EMBEDMENT/PIPE INSTALLATION.
- PAINT PIPE SURFACES THAT WILL BE CONCEALED BY PIPE SUPPORTS PRIOR TO INSTALLING PIPE.
- COORDINATE NEW WORK WITH DEMOLITION.
- ALL BURIED/EXPOSED PIPE JOINTS NEW AND EXISTING FOR NEW PIPING INSTALLATIONS TO BE RESTRAINED, UNLESS NOTED OTHERWISE.
- ENCASE BURIED PIPING UNDER STRUCTURES WITH 1'-0" MINIMUM CONCRETE ENCASEMENT AROUND PIPE AND FROM FURTHERST EXTENSIONS OF FITTING JOINTS. AFTER PIPE HAS BEEN PRESSURE TESTED.
- FIELD VERIFY THAT ALL EXISTING PIPE PENETRATIONS, WALL SLEEVES AND WALL PIPES ARE AS SHOWN ON PLANS.
- FOR PURPOSE OF CLARITY, NOT ALL PIPING AND VALVES MAY BE SHOWN IN PLAN VIEWS. SEE PROCESS SCHEMATICS FOR COMPLETE DETAILS.

PROCESS SITE PIPING NOTES

- VERIFY DEPTH, SIZE, MATERIAL AND LOCATION OF ALL EXISTING BELOW GRADE PIPING FOR NEW BURIED PIPE INSTALLATION, PRIOR TO COMMENCING WORK.
- COORDINATE CONSTRUCTION WITH ENGINEER/OWNER TO MAINTAIN PLANT/FACILITY NORMAL MODE OF OPERATION.
- FIELD VERIFY ALL EXISTING UTILITIES AND BURIED PIPING PRIOR TO ABANDONMENT AND INSTALLATION OF PIPING.
- INSTALL VALVE BOXES ON ALL BELOW GRADE VALVES.
- USE APPROPRIATE FITTINGS AND/OR PIPE JOINT DEFLECTION AS NECESSARY TO INSTALL PIPE AT INVERTS AND ELEVATIONS INDICATED.
- RESTRAIN ALL NEW BURIED MECHANICAL JOINT PIPE AND NEW TIE-IN CONNECTIONS TO EXISTING PIPE.

PROCESS CHEMICAL FEED NOTES

- CHEMICAL FEED PIPING SHOWN FOR GENERAL ROUTING AND CHEMICAL FEED POINT LOCATIONS ONLY. ROUTE PIPING AS NECESSARY TO AVOID CONFLICTS AND INSTALL PIPING AND VALVES IN ACCORDANCE WITH THE CHEMICAL FEED SYSTEM SCHEMATIC DIAGRAMS.
- DO NOT MOUNT VALVES HIGHER THAN 6 FEET ABOVE FINISHED FLOOR.
- PUMP SHELVES TO BE COMPATIBLE WITH CHEMICAL SERVICE. MOUNT PUMP SHELVES 3 FEET ABOVE FINISHED FLOOR UNLESS NOTED OTHERWISE.

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR CONSTRUCTION

REVISIONS

6/9/2026	30% PRELIMINARY DESIGN
6/20/2026	30% PEER REVIEW
Drawn By	JKING
Designer	JKING
Reviewer	JREDNER
Manager	ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.


PROJECT NO.

241369


SHEET NO.

P001


PIPE/FITTINGS SYMBOLS



VALVE SYMBOLS



ACTUATOR SYMBOLS



THE FOLLOWING ADDITIONAL DESIGNATIONS MAY BE UTILIZED ADJACENT TO SOME VALVE OR GATE SYMBOLS.

NC - NORMALLY CLOSED


NO - NORMALLY OPEN

FC - FAILS CLOSED


FO - FAILS OPEN

FP - FAILS IN LAST KNOWN POSITION


GATE SYMBOLS




BLOWER/COMPRESSOR SYMBOLS




PUMP SYMBOLS




EQUIPMENT SYMBOLS




PRIMARY ELEMENT SYMBOLS




EQUIPMENT TAG NUMBERS



PIPELINE IDENTIFICATION NUMBERS



LINE SYMBOLS



GENERAL SHEET NOTES

- THIS IS A STANDARD LEGEND SHEET. THEREFORE, NOT ALL OF THE INFORMATION SHOWN MAY BE USED ON THIS PROJECT.
- CONTACT ENGINEER FOR SYMBOLS USED BUT NOT SHOWN ON THIS DRAWING.

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
6/29/2026	30% PEER REVIEW
Drawn By	JKING
Designer	JKING
Reviewer	JREDNER
Manager	ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.
241369
SHEET NO.

P002

DEVICE TYPE DEFINITIONS					
LETTER	FIRST LETTER		SUCCEEDING LETTERS		
	PROCESS OR INITIATING VARIABLE	MODIFIER	READOUT OR PASSIVE FUNCTION	OUTPUT FUNCTION	MODIFIER
A	ANALYSIS		ALARM		
B	BURNER FLAME, COMBUSTION		USER'S CHOICE	USER'S CHOICE	USER'S CHOICE
C	CONDUCTIVITY			CONTROL (WITH FEEDBACK)	CLOSE OR CLOSED
D	DENSITY OR SPECIFIC GRAVITY	DIFFERENTIAL			DEVIATION
E	VOLTAGE		SENSOR, PRIMARY ELEMENT		
F	FLOW, FLOW RATE	RATIO			
G	GAUGE		GLASS, GAUGE, VIEW		
H	HAND/MANUAL				HIGH
I	CURRENT		INDICATE		
J	POWER		SCAN		
K	TIME, SCHEDULE	RATE OF CHANGE		CONTROL STATION (NO FEEDBACK)	
L	LEVEL		LIGHT (PILOT)		LOW
M	MOTION OR MOTOR	MOMENTARY			MIDDLE, INTERMEDIATE
N	TORQUE		USER'S CHOICE	USER'S CHOICE	USER'S CHOICE
O	USER'S CHOICE		ORIFICE, RESTRICTION		OPEN OR OPENED
P	PRESSURE OR VACUUM		POINT (TEST CONNECTION)		
Q	QUANTITY	INTEGRATE, TOTALIZE	INTEGRATE, TOTALIZE		
R	RADIOACTIVITY		RECORD OR PRINT		RUN
S	SPEED OR FREQUENCY	SAFETY		SWITCH	STOP
T	TEMPERATURE			TRANSMIT	
U	MULTIVARIABLE		MULTIFUNCTION	MULTIFUNCTION	
V	VISCOSITY OR VIBRATION			VALVE	
W	WEIGHT OR FORCE		WELL PROBE		
X	UNCLASSIFIED	X-AXIS	UNCLASSIFIED	UNCLASSIFIED	UNCLASSIFIED
Y	EVENT, STATE	Y-AXIS		RELAY OR COMPUTE	
Z	POSITION	Z-AXIS		DRIVER, ACTUATOR, CONTROL	

GENERAL SYMBOLS

	FIELD/LOCAL DEVICE
	CONTROL PANEL DEVICE FACE-MOUNTED
	CONTROL PANEL DEVICE INTERIOR-MOUNTED
	MCC DEVICE FACE-MOUNTED
	MCC DEVICE INTERIOR-MOUNTED
	LOGICAL INTERLOCK

LINE SYMBOLS

	PROCESS CONTROL LINE
	DISCRETE SIGNAL
	ANALOG SIGNAL
	FIBER OPTIC CABLE
	UNSHIELDED TWISTED PAIR CABLE
	WIRELESS ETHERNET
	PNEUMATIC PIPING/SIGNAL
	HYDRAULIC PIPING/SIGNAL

I/O SYMBOLS

	DISCRETE PLC INPUT
	ANALOG PLC INPUT
	DISCRETE PLC OUTPUT
	ANALOG PLC OUTPUT
	CONTROL PANEL INPUT/OUTPUT INTERIOR-MOUNTED

INSTRUMENTATION TAG NUMBERS

	LOCAL DEVICE X = DEVICE TYPE Y = LOOP NUMBER
	PANEL MOUNTED DEVICE X = DEVICE TYPE Y = LOOP NUMBER

ABBREVIATIONS

AIT	ANALYZER-INDICATING TRANSMITTER
AE	ANALYZER SENSOR
AV/SV	VALVE CONTROL
CP	CONTROL PANEL
CS	CONTROL SWITCH
ESPB	EMERGENCY STOP PUSH BUTTON
FE	FLOW ELEMENT
FI	FLOW INDICATOR
FIT	FLOW INDICATING TRANSMITTER
FIQ	FLOW INDICATING TOTALIZER
FR	FLOW RECORDER
FS	FLOW SWITCH
FT	FLOW TRANSMITTER
HOA	HAND/OFF/AUTO
HS	HAND SWITCH
JA	POWER ALARM
JIT	POWER TRANSMITTER
JY	POWER EVENT (FAIL)
KS	TIME DELAY
LAH	LEVEL ALARM HIGH
LAHH	LEVEL ALARM HIGH HIGH
LAL	LEVEL ALARM LOW
LALL	LEVEL ALARM LOW LOW
LE	LEVEL ELEMENT
LI	LEVEL INDICATOR
LS	LEVEL SWITCH
LSL	LEVEL SWITCH LOW
LSLL	LEVEL SWITCH LOW LOW
LSH	LEVEL SWITCH HIGH
LSHH	LEVEL SWITCH HIGH HIGH
LT	LEVEL TRANSMITTER
LIC	LEVEL INDICATING CONTROLLER
LIT	LEVEL INDICATING TRANSMITTER
MCC	MOTOR CONTROL CENTER
MCP	MAIN CONTROL PANEL
ML	MOTION LIGHT
PAH	PRESSURE ALARM HIGH
PAL	PRESSURE ALARM LOW
PE	PRESSURE ELEMENT
PI	PRESSURE INDICATOR
PIT	PRESSURE INDICATING TRANSMITTER
PS	PRESSURE SWITCH
PSH	PRESSURE SWITCH HIGH
PSL	PRESSURE SWITCH LOW
PT	PRESSURE TRANSMITTER
SC	SPEED CONTROL OR CONTROLLER
ST	SPEED TRANSMITTER
SV	SOLENOID VALVE
TS (H/L)	TEMPERATURE SWITCH (HIGH/LOW) (HH=HIGH HIGH) (LL=LOW LOW)
TT	TEMPERATURE TRANSMITTER
VFD	VARIABLE FREQUENCY DRIVE
WE	WEIGHT ELEMENT
WIT	WEIGHT INDICATING TRANSMITTER
WT	WEIGHT TRANSMISSION SIGNAL
XL/ML	EVENT OR STATUS (I.E. RUNNING)
YA/QA	EVENT ALARM (I.E. FAULT)
YS	EVENT SWITCH
ZC	POSITION CONTROL
ZCC	CLOSE POSITION CONTROL
ZCO	OPEN POSITION CONTROL
ZS	POSITION SWITCH
ZSA	EMERGENCY CLOSE CONTROL (ALARM)
ZSC	CLOSED POSITION (LIMIT) SWITCH
ZSM	INTERMEDIATE POSITION (LIMIT) SWITCH (I.E. 95% CLOSED)
ZSO	OPENED POSITION (LIMIT) SWITCH
ZT	POSITION TRANSMITTER (STATUS)

GENERAL SHEET NOTES

- THIS IS A STANDARD LEGEND SHEET. THEREFORE, NOT ALL OF THE INFORMATION SHOWN MAY BE USED ON THIS PROJECT.
- CONTACT ENGINEER FOR DEFINITIONS, SYMBOLS, AND ABBREVIATIONS USED BUT NOT SHOWN ON THIS DRAWING.

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
6/20/2026	30% PEER REVIEW

Drawn By	JKING
Designer	JKING
Reviewer	JREDNER
Manager	ERINS


Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.
241369

SHEET NO.

P003

PLOT INFO: Z:\2024\241369\CADD\DWG\0241369.DWG LAYOUT: P102 DATE: 6/12/2026 TIME: 10:11:4 AM USER: JKWG



OVERALL FLOW SCHEMATIC
NO SCALE

SYMBOL LEGEND

NOTES

1. NOTE TEXT HERE...

KEY NOTES

1. KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

06/02/2026	30% PRELIMINARY DESIGN
02/29/2026	30% PEER REVIEW
Drawn By	AKRAUSS
Designer	ZKIRSCHMAN
Reviewer	JREDNER
Manager	ERINS


Hard copy is intended to be
24"x36" when plotted. Scale(s)
indicated and graphic quality may
not be accurate for any other size.

PROJECT NO.
241369
SHEET NO.

P102

©Copyright 2026
All Rights Reserved

PLOT INFO: Z:\2024\241369\CAD\CDP\02241369.DWG LAYOUT: P103 DATE: 8/21/2026 TIME: 2:35:37 PM USER: KING



SOLIDS FLOW SCHEMATIC
NO SCALE

NOTES

1. NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

8/12/2026	PROGRESS SET
8/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW

Drawn By	AKRAUSS
Designer	EEDWARDS
Reviewer	JREDNER
Manager	ERINS


Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.
241369

SHEET NO.

P103

©Copyright 2026
All Rights Reserved



PRELIMINARY AND PRIMARY TREATMENT FLOW SCHEMATIC AND P&ID

NO SCALE

SYMBOL LEGEND

NOTES

1. NOTE TEXT HERE...

 KEY NOTES

1. KEY NOTE TEXT HERE...

How to

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

REVISIONS

NOT FOR
CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW

Drawn By	ZKIRSCHMAN
Designer	ZKIRSCHMAN
Reviewer	JREDNER
Manager	ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.


241369

SHEET NO.

P105

©Copyright 2026
All Rights Reserved

PLOT INFO: Z:\2024\241369\CAD\CDP\05241369.DWG LAYOUT: P106 DATE: 6/12/2026 TIME: 10:11:16 AM USER: J.KING



SECONDARY CLARIFIER
FLOW SCHEMATIC AND P&ID
NO SCALE

NOTES

1. NOTE TEXT HERE...

KEY NOTES

1. KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW

Drawn By	
Designer	
Reviewer	
Manager	ERINS

Hard copy is intended to be
24"x36" when plotted. Scale(s)
indicated and graphic quality may
not be accurate for any other size.


PROJECT NO.
241369

SHEET NO.

P106

©Copyright 2026
All Rights Reserved

PLOT INFO Z:\2024\241369\CAD\CDP\07241369.DWG LAYOUT: P107 DATE: 6/12/2026 TIME: 10:11:17 AM USER: J.KING



DIGESTERS
FLOW SCHEMATIC AND P&ID
NO SCALE

SYMBOL LEGEND

NOTES

1. NOTE TEXT HERE...

KEY NOTES

1. KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION


6/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW
Drawn By	EEDWARDS
Designer	EEDWARDS
Reviewer	JREDNER
Manager	ERINS

Hard copy is intended to be
24"x36" when plotted. Scale(s)
indicated and graphic quality may
not be accurate for any other size.

PROJECT NO.	241369
SHEET NO.	

P107

©Copyright 2026
All Rights Reserved



DIGESTER GAS
FLOW SCHEMATIC AND P&ID
NO SCALE

SYMBOL LEGEND

NOTES

- NOTE TEXT HERE...

KEY NOTES

- KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

06/02/2026 30% PRELIMINARY DESIGN
05/29/2026 30% PEER REVIEW

Drawn By EEDWARDS
Designer EEDWARDS
Reviewer JREDNER
Manager ERINS

Hard copy is intended to be
24"x36" when plotted. Scale(s)
indicated and graphic quality may
not be accurate for any other size.


PROJECT NO.
241369

SHEET NO.


P108

©Copyright 2026
All Rights Reserved

PLOT INFO: Z:\2024\241369\CAD\CDP\00241369.DWG LAYOUT: P109 DATE: 6/12/2026 TIME: 10:11:19 AM USER: J.KING



CHEMICAL SYSTEMS
FLOW SCHEMATIC AND P&ID
NO SCALE



SYMBOL LEGEND

NOTES

- NOTE TEXT HERE...

KEY NOTES

- KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

0/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW
Drawn By	ZKIRSCHMAN
Designer	ZKIRSCHMAN
Reviewer	JREDNER
Manager	ERINS

Hard copy is intended to be
24"x36" when plotted. Scale(s)
indicated and graphic quality may
not be accurate for any other size.

PROJECT NO.
241369

SHEET NO.

P109


©Copyright 2026
All Rights Reserved

Appendix



3

ONE LINE FEEDER LEGEND			
TAG	DESCRIPTION - (3)COND+G	TAG	DESCRIPTION - (4)COND+G
1	3#12, #12G, 3/4°C	1N	4#12, #12G, 3/4°C
2	3#10, #10G, 3/4°C	2N	4#10, #10G, 3/4°C
3	3#8, #10G, 3/4°C	3N	4#8, #10G, 3/4°C
4	3#6, #10G, 1°C	4N	4#6, #10G, 1°C
5	3#4, #8G, 1 1/4°C	5N	4#4, #8G, 1 1/4°C
6	3#3, #8G, 1 1/4°C	6N	4#3, #8G, 1 1/2°C
7	3#2, #6G, 1 1/2°C	7N	4#2, #8G, 1 1/2°C
8	3#1, #6G, 2°C	8N	4#1, #6G, 2°C
9	3-1/0, #6G, 2°C	9N	4-1/0, #6G, 2°C
10	3-2/0, #6G, 2°C	10N	4-2/0, #6G, 2°C
11	3-3/0, #6G, 2 1/2°C	11N	4-3/0, #6G, 2 1/2°C
12	3-4/0, #4G, 2 1/2°C	12N	4-4/0, #6G, 2 1/2°C
13	3-250kcmil, #4G, 3°C	13N	4-250kcmil, #4G, 3°C
14	3-300kcmil, #4G, 3°C	14N	4-300kcmil, #4G, 3°C
15	3-350kcmil, #4G, 3°C	15N	4-350kcmil, #4G, 4°C
16	3-500kcmil, #3G, 4°C	16N	4-400kcmil, #4G, 4°C
17	(2)3-250kcmil, #2G, 3°C	17N	4-500kcmil, #3G, 4°C
18	(2)3-350kcmil, #1G, 3°C	18N	4-600kcmil, #3G, 4°C
19	(2)3-400kcmil, 1/0G, 4°C	19N	(2)4-300kcmil, #2G, 3°C
20	(2)3-500kcmil, 1/0G, 4°C	20N	(2)4-400kcmil, #1G, 4°C
21	(3)3-400kcmil, 2/0G, 4°C	21N	(2)4-500kcmil, 1/0G, 4°C
22	(4)3-350kcmil, 3/0G, 4°C	22N	(2)4-600kcmil, 1/0G, 4°C
23	(4)3-500kcmil, 4/0G, 4°C	23N	(3)4-500kcmil, 2/0G, 4°C
24	(5)3-400kcmil, 4/0G, 4°C	24N	(4)4-400kcmil, 3/0G, 4°C
25	(6)3-400kcmil, 250kcmil G, 4°C	25N	(4)4-600kcmil, 4/0G, 4°C
26	(7)3-500kcmil, 350kcmil G, 4°C	26N	(6)4-350kcmil, 4/0G, 4°C
27	(8)3-500kcmil, 400kcmil G, 4°C	27N	(6)4-500kcmil, 250kcmil G, 4°C
		28N	(7)4-600kcmil, 350kcmil G, 4°C
		29N	(8)4-600kcmil, 400kcmil G, 4°C



ONE LINE DIAGRAM
4800V; 480Y/277V-3Ø-4W

NOTES

- EQUIPMENT, CONDUIT, AND LOADS IN LIGHTER LINE WEIGHTS ARE EXISTING, UNLESS NOTED OTHERWISE.

KEY NOTES

- KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR
CONSTRUCTION

6/9/2026	30% PRELIMINARY DESIGN
5/29/2026	30% PEER REVIEW


Drawn By TDWYER
Designer TDWYER
Reviewer
Manager ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.
241369




SHEET NO.

E401



1. KEY NOTE TEXT HERE...

ONE LINE DIAGRAM



NOTES

1. EQUIPMENT, CONDUIT, AND LOADS IN LIGHTER LINE WEIGHTS ARE EXISTING, UNLESS NOTED OTHERWISE.

KEY NOTES

1. KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

REVISIONS

NOT FOR CONSTRUCTION

06/2/2026	30% PRELIMINARY DESIGN
02/29/2026	30% PEER REVIEW

Drawn By	TDWYER
Designer	TDWYER
Reviewer	
Manager	ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.

241369

SHEET NO.


E403

©Copyright 2026
All Rights Reserved

fishbeck
Engineers | Architects | Scientists | Constructors

ONE LINE DIAGRAM
480V-3φ-3W; 120/240V-3φ-3W

PLOT INFO Z:\2024\1369\CD\CD-E404\124\1369.DWG LAYOUT: E404 DATE: 6/6/2026 TIME: 3:27:03 PM USER: TDWYER



NOTES

1. EQUIPMENT, CONDUIT, AND LOADS IN LIGHTER LINE WEIGHTS ARE EXISTING, UNLESS NOTED OTHERWISE.

KEY NOTES

1. KEY NOTE TEXT HERE...

Southwater MUA

St. Clair County, Michigan

St. Clair County-Algonac WWTP Improvements

NOT FOR CONSTRUCTION

6/9/2026 30% PRELIMINARY DESIGN

5/29/2026 30% PEER REVIEW

Drawn By TDWYER

Designer TDWYER

Reviewer

Manager ERINS

Hard copy is intended to be 24"x36" when plotted. Scale(s) indicated and graphic quality may not be accurate for any other size.

PROJECT NO.

241369

SHEET NO.

E404

©Copyright 2026 All Rights Reserved