

EXPERTS IN TESTING AND CERTIFICATION SINCE 1954



42777 TRADE WEST DRIVE, STERLING, VA 20166

571-300-7050 | EXPERTS@CAPITALTESTING.ORG | WWW.CAPITALTESTING.ORG

FORMERLY HPVA LABORATORIES®

Certificate Of Flame Spread Compliance

SC EGGER Romania SRL

Str. Austriei 2, 725400 Radauti, jud. Suceava Romania

Capital Testing officially recognizes this mill's production as certified to meet the specified flame spread index (FSI) and smoke developed index (SDI) ranges stated in this certificate. Class designations based on ASTM E84 test results are those defined by the International Code Council (ICC) model building codes and the National Fire Protection Association (NFPA) Life Safety Code, NFPA 101 (see table below). The products covered under this certification are also certified to meet the specified flame spread rating (FSR) and smoke developed classification (SDC) ranges stated in this certificate, as identified through CAN/ULC-S102 testing. The National Building Code of Canada (NBC) contains FSR and SDC criteria for various building products.

Class	Flame Spread Index (FSI)	Smoke Developed Index (SDI)
A	25 or less	450 or less
B	26 - 75	450 or less
C	76 - 200	450 or less

The products listed in this certificate may now carry the Capital Testing certification label. Certification is granted to this facility based on third party-audited conformance and commitment to the quality control procedures necessary to ensure production meets the respective class designation and/or performance ranges listed on page 2 and 3, as well as confirmation through semi-annual testing of each product type in accordance with the ASTM E84 standard and annual testing in accordance with the CAN/ULC-S102 standard.

Effective Date:

June 4th, 2025

Expiration Date:

June 4th, 2027



Josh Hosen,
Managing Director, Capital Testing

EXPERTS IN TESTING AND CERTIFICATION SINCE 1954



42777 TRADE WEST DRIVE, STERLING, VA 20166

571-300-7050 | EXPERTS@CAPITALTESTING.ORG | WWW.CAPITALTESTING.ORG

FORMERLY HPVA LABORATORIES®

Certificate Of Flame Spread Compliance

SC EGGER Romania SRL

Str. Austriei 2, 725400 Radauti, jud. Suceava Romania

Scope of Certification

Product Type(s)	Flame Spread Index (FSI) / Smoke Developed Index (SDI) Range and Class Designation	Test Method
7/16" – 23/32" Oriented Strand Board (OSB) with Intumescent Coating (one- and two-side coated) Product Name: EGGER OSB Flammex Coating Color: White	25 or less FSI, 450 or less SDI Class A	ASTM E84

NOTE: test results are based on testing self-supporting panels in the Steiner tunnel.

Effective Date:

June 4th, 2025

Expiration Date:

June 4th, 2027



Page 2 of 3

Josh Hosen,
Managing Director, Capital Testing

EXPERTS IN TESTING AND CERTIFICATION SINCE 1954



42777 TRADE WEST DRIVE, STERLING, VA 20166

571-300-7050 | EXPERTS@CAPITALTESTING.ORG | WWW.CAPITALTESTING.ORG

FORMERLY HPVA LABORATORIES®

Certificate Of Flame Spread Compliance

SC EGGER Romania SRL

Str. Austriei 2, 725400 Radauti, jud. Suceava Romania

Scope of Certification

Product Type(s)	Flame Spread Rating (FSR) / Smoke Developed Classification (SDC) Range	Test Method
7/16" – 23/32" Oriented Strand Board (OSB) with Intumescent Coating (one- and two-side coated) Product Name: EGGER OSB Flammex Coating Color: White	25 or less FSR, 450 or less SDC	CAN/ULC-S102

NOTE: test results are based on testing self-supporting panels in the Steiner tunnel.

Effective Date:

June 4th, 2025

Expiration Date:

June 4th, 2027



Page 3 of 3

Josh Hosen,
Managing Director, Capital Testing