

**KEMPER RECREATION PARK IMPROVEMENTS  
185 PONDEROSA AVENUE  
DeKALB, MS**

**ADDENDUM NO. 1**

TO: ALL BIDDERS ON THE ABOVE REFERENCED PROJECT

FROM: Phillip McDonald, PE

DATE: June 11, 2026

SUBJECT: ADDENDUM NO. 1

- I. **CLARIFICATION** - Bid date is FRIDAY June 19, 2026
- II. **CHANGE** (Plan sheet C6.0) Rate of application for Tifway Bermuda grass sprigs shall be 600 bushels/acre.
- III. **FENCING CLARIFICATIONS:**
  - a. Backstop is 20' high PLUS the 5' hood.
  - b. Middle rail is required at corners only.
  - c. Corner posts to be 3"dia.; interim posts tp be 2 3/8"; schedule 20

Submitted By:



Liz Dudley, Project Manager  
Engineering Plus, Inc.

June 11, 2026

Date

\_\_\_\_\_  
Contractor

\_\_\_\_\_  
Date

**THIS ADDENDUM SHALL BE SIGNED, DATED AND SUBMITTED WITH BID DOCUMENTS. FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND ATTACH IT TO BID DOCUMENTS MAY BE GROUNDS FOR REJECTION OF BID..**