

**KEMPER COUNTY LIBRARY RENOVATIONS  
KEMPER NEWTON REGIONAL LIBRARY SYSTEM  
DeKALB, MS**

**ADDENDUM NO. 2**

TO: ALL BIDDERS ON THE ABOVE REFERENCED PROJECT

FROM: Phillip McDonald, PE

DATE: April 13, 2026

SUBJECT: ADDENDUM NO. 2

**1. SHEET D1.0 – FLOOR PLAN – SELECTIVE DEMOLITION**

- a. Existing Staff Bathroom (STORAGE 110)
  - i. **ADD:** the following:
    - 1. NOTE 6. REMOVE EXISTING CERAMIC TILE FROM WALLS.
    - 2. NOTE 7. REMOVE EXISTING PLUMBING FIXTURES (as indicated). EXISTING DOMESTIC COLD & HOT WATER PIPING, SANITARY SEWER PIPING AND SANITARY SEWER VENT PIPING TO REMAIN. CAP ABANDONED SUPPLY & WASTE PIPING.
    - 3. NOTE 10. REMOVE EXISTING WALL CONSTRUCTION (wing wall as indicated).
- b. Existing Hallway (HALL 112)
  - i. **ADD:** the following:
    - 1. NOTE 1. REMOVE EXISTING SUSPENDED ACOUSTICAL CEILING TILE & GRID.
    - 2. NOTE 3. REMOVE EXISTING FLOORING & BASE. REMOVE EXISTING ADHESIVES, ETC. TO CLEAN CONC. SLAB.
    - 3. NOTE 4. REMOVE EXISTING LIGHT FIXTURES. DEVICE BOXES & CONDUCTORS TO REMAIN FOR REUSE AS INDICATED.

**2. SHEET A2.0 – EXTERIOR ELEVATIONS**

- a. **CLARIFICATION:** The existing roof shall be re-roofed with architectural shingles as indicated on the elevations.
- b. **ADD:** replace existing gutters and downspouts. Add gutter and downspout at new entrance.

Submitted By:



\_\_\_\_\_  
Liz Dudley, Project Manager  
Engineering Plus, Inc.

\_\_\_\_\_  
Contractor

April 13, 2026  
Date

\_\_\_\_\_  
Date

**THIS ADDENDUM SHALL BE SIGNED, DATED AND SUBMITTED WITH BID DOCUMENTS. FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND ATTACH IT TO BID DOCUMENTS MAY BE GROUNDS FOR REJECTION OF BID..**