

ADDENDUM NO. 2

Nature Area Canoe Landing

VILLAGE OF GLANDORF, OHIO

ISSUED TO:
Current Plan Holders & Affiliated Reporting Companies

Date Issued: Monday, December 8, 2025
Number of Pages: 4

ISSUED BY:
Bockrath & Associates Engineering and Surveying, LLC
115 S. Fair Avenue, Suite A
Ottawa, Ohio 45875
Phone: 419-523-5789
Fax: 419-523-5799

**Please note the project bid date:
Thursday, December 11, 2025, 9:00 a.m.**

An Addendum Receipt must be Returned prior to Bid Opening.

Plan Holders

Current plan holders list is attached.

Clarification #1 - Can you clarify bid item #3? Is that calculation based on fill material on the outside of the access drive/parking lot, or is it for fill material needed under the access drive/parking lot to bring it up to subgrade? **Total Embankment for subgrade and shoulders.**

Clarification #2 – Can you clarify the type of stone to be used under the concrete steps? Drawings show #57 stone on sheet 5 but it also has #57 stone under the concrete parking lot. **#57 Aggregate under Steps and Landing and #304 Aggregate for Drive and Parking Lot Base.**

Question #1 Depending on the water level we might need to use cofferdams to control the water while the concrete work is performed. Is that what you have seen on other projects similar to this? **No work is to be performed in the stream.** Would the ODNR or Army Corp need to be notified? **No.**

Question #2 Is it too late to put some grading limits on the plans so we can figure out a seeding quantity? Use 0.90 Acres for Limits of Grading, Seeding & Restoration. A more detailed grading plan can be provided for the successful bidder.

Question #3 - What's the buildup for the asphalt apron? Due to the limited quantity and light use could we do 3 lifts of surface? 6 inches of #304 Aggregate for base and 6" of #441 Asphalt Concrete, Type 1 (449) PG 64-22

Question #4 - What type of stone for the walking path? #57 Stone

Question #5 - Does your engineer's estimate include the alternate or is that for the base bid only? Base Bid only. Base Bid Estimate Revised to \$275,000 per addendum #1

ADDENDUM RECEIPT #2

Plan holder is required fill out the bottom section and fax or email to issuing office to acknowledge receipt of this addendum.

**I hereby acknowledge receipt of
Addendum Number 1
issued for:**

**Nature Area Canoe Landing
VILLAGE OF GLANDORF, OHIO**

ISSUED BY:

Bockrath & Associates Engineering and Surveying, LLC
115 S. Fair Avenue, Suite A
Ottawa, Ohio 45875
Phone: 419-523-5789
Fax: 419-523-5799

**Please note the project bid date:
Thursday, December 11, 2025, 9:00 a.m.**

**Addendum Receipt must be Returned prior to
Bid Opening**

Please remit to troy@bockrath-es.com or fax to 419-523-5799

Receipt of Addendum Acknowledgement

Company Name: _____

Signature: _____

Printed Name: _____

Date: _____

Plan Holders
Village of Glandorf
Nature Area Canoe Landing

Bid Date: Thursday, December 11, 2025, at 9:00 a.m.

Updated 12/8/25 – Project #23-081

Village of Glandorf, Ohio (owner)
203 N. Main St., PO Box 154
Glandorf, OH 45848
Ph: 419-538-6953
sstechschulte@villageofglandorf.com

Dangler Excavating, LLC
342 W. Wall St.
Paulding, OH 45879
419-670-4711
michael_dangler@danglerexcavating.com

Hohenbrink Excavating
684 Tawa Drive
Ottawa, OH 45875
Ph: 419-427-3444
Fax 419-523-5506
nhohenbrink@hohenbrinkexcavating.com

Vanderpool Excavating Inc
0130 County Road
Forest, Ohio 45843
Ph. 419-310-5029
tyler@vanderpooleexcavating.com

Fenson Contracting
17670 SR 190
Fort Jennings, OH 45844
Ph: 419-286-2458
nolan.kaverman@fensoncontracting.com

Schimmoeller Construction, Inc.
18240 SR 114
Kalida, OH 45853
Ph: 419-532-2058
john@schimmoellerconstruction.com

ADJ Excavating
10488 Road 4
Leipsic, OH 45856
Ph: 419-969-9254
adjexcavating@outlook.com

Maas Brothers Excavating and Hauling, LLC
200-A Woodland Drive
Ottawa, OH 45875
Ph: 419-890-6555
Maasbrothers4@gmail.com