

1502 South Huntington Street Sulphur, Louisiana 70663 Phone: (337) 527-8137 www.vsgarchitects.com

ADDENDUM #2

Cameron Parish Law Enforcement District New Maintenance Facility Grand Lake Law Enforcement Center Alfred Duhon Road Grand Lake, LA VSG Project No. 2458B

Date Issued: September 23, 2025

NOTE: The following clarifications, changes, additions, or deletions to the Drawings and Specifications shall hereby be incorporated into the Contract Documents for the above referenced project. This addendum supersedes all contrary and conflicting information contained in previous Addenda, Drawings and Specifications and are hereby amended. Prime Bidders shall acknowledge receipt of all Addenda in the space on the Bid Form.

ADDENDUM ITEMS:

- 1. Clarification: #2 CU on Conductor for Generator.
- 2. Prior Approval: Sesco Lighting dated 9/18/25 is approved.
- 3. Door Hardware Clarification: Doors 6, 8, and 1 are aluminum doors and frames. Aluminum Door supplier shall furnish complete with closer, threshold and weather stripping and dead-bolt lockset. Hollow Metal Doors shall be complete with 1.5 pair of hinges, silencers, and medium duty locksets.
- 4. Clarification: All electrical charges by Jeff Davis Electric shall be paid by Sheriff.
- 5. Clarification: Basic Wind Speed of Building shall be 151 mph.

Attachments:

none

TOTAL PAGES IN THIS ADDENDUM = 1 PAGE

End of Addendum