

**Addendum No. 3**

Paving and Exterior Improvements at Various Calcasieu Parish Libraries Project  
Various Locations, Calcasieu Parish, LA  
Project No.: DB-2025-FM-149

Calcasieu Parish Police Jury  
1015 Pithon Street  
Lake Charles, LA

**TO ALL CONTRACTORS:**

This Addendum is hereby made a part of the Contract Documents dated May 5, 2025 and prepared by Brossett Architect, LLC.

The following items shall be considered part of the Contract Documents and shall be included in the same upon executions of the Contract. Changes made by Addenda take precedence over information published at an earlier date. Any changes, which may affect construction or proper installation of materials, equipment or structures, not specifically mentioned in this addendum, shall be brought to the attention of the Architect before submitting bid. Otherwise, such conditions, if found later to exist, must be worked out in an acceptable manner at no additional cost to the Owner.

It is understood and agreed that the following alterations, changes and/or omissions shall be made in the Plans and the Specifications, as now drawn and written, and that such alterations, changes and/or omissions shall be incorporated in the project during construction. Unless such an alteration, change and/or omission is specifically mentioned in this addendum, the plans and specifications as now drawn and written, shall govern in all respects.

Acknowledge receipt of this Addendum on the Bid Form.

Bidders are advised to call attention of all sub-bidders and suppliers to all information and changes which may affect their work.

This addendum consists of a total of 5 pages.

**PART 1 – Drawing Modifications**

1. No drawing modifications.

**PART 2- Project Manual Modifications**

1. Spec 096513: Attached specification 096513 to be made a part of the project manual.
2. Spec 096516: Attached Specification 096516 to be made part of the project manual.
3. Spec 096813: Walk off carpet to be J & J, Incognito Walk Off Modular or approved equal.

END OF ADDENDUM NO. 3

## **SECTION 096513 - RESILIENT BASE AND ACCESSORIES**

### **PART 1 - GENERAL**

#### **1.1 SECTION REQUIREMENTS**

- A. Submittals: Product Data and Samples.
- B. Extra Materials: Deliver to Owner at least 50 linear feet of each type and color of resilient wall base installed.

### **PART 2 - PRODUCTS**

#### **2.1 RESILIENT BASE**

- A. Color and Pattern: As selected by Architect.
- B. ASTM F 1861, Type TP (rubber, thermoplastic).
- C. Group (Manufacturing Method): I (solid, homogeneous).
- D. Style: Cove (base with toe) or Straight (flat or toeless). Straight at carpet, cove at all other areas.
- E. Minimum Thickness: 0.125 inch.
- F. Height: 4 inches.
- G. Lengths: Coils in manufacturer's standard lengths.
- H. Outside Corners: Job formed.
- I. Inside Corners: Job formed.
- J. Finish: Satin.

#### **2.2 INSTALLATION ACCESSORIES**

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement- or blended hydraulic cement-based formulation provided or approved by flooring manufacturer for applications indicated.
- B. Adhesives: Water-resistant type recommended by manufacturer to suit products and substrate conditions.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Prepare concrete substrates according to ASTM F 710. Verify that substrates are dry and free of curing compounds, sealers, and hardeners.
- B. Adhesively install resilient wall base and accessories.
- C. Install wall base in maximum lengths possible. Apply to walls, columns, pilasters, casework, and other permanent fixtures in rooms or areas where base is required.

**END OF SECTION 096513**

## **SECTION 096516 - RESILIENT FLOORING**

### **PART 1 - GENERAL**

#### **1.1 SECTION REQUIREMENTS**

- A. Submittals: Product Data and Samples.
- B. Extra Materials: Deliver to Owner at least 50 linear feet, in form and in full width, for each type and color of resilient flooring installed.

### **PART 2 - PRODUCTS**

#### **2.1 LUXURY VINYL FLOOR COVERING (LVT)**

- A. Products:
  - 1. Mannington, Spacia Collection Abstract Stone.
- B. Color and Pattern: As selected by Architect.
- C. Vinyl Floor Covering with Backing: ASTM F 1700, Type III, Grade B.
  - 1. Overall Thickness: 0.98
  - 2. Wear Material: 20 mil.
  - 3. Backing Class: Class A (fibrous).
- D. Fire-Test Response: Critical radiant flux classification of Class I, not less than 0.45 W/sq. cm per ASTM E 648.
- E. Wearing Surface: Embossed.
- F. Size: 12" x 18"

#### **2.2 INSTALLATION ACCESSORIES**

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement- or blended hydraulic cement-based formulation provided or approved by flooring manufacturer for applications indicated.
- B. Adhesives: Water-resistant type recommended by manufacturer to suit vinyl floor covering and substrate conditions indicated.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Prepare concrete substrates according to ASTM F 710. Verify that substrates are dry and free of curing compounds, sealers, and hardeners.
- B. Provide floor moisture barrier as specified.
- C. Maintain uniformity of resilient flooring direction, and match edges for color shading at seams.

**END OF SECTION 096516**