

TO THE DRAWINGS AND THE PROJECT MANUAL

PROJECT: ADDITIONS TO WESTWOOD ELEMENTARY
LOCATION: WESTLAKE, LOUISIANA
OWNER: CALCASIEU PARISH SCHOOL BOARD
KAI PROJECT NO. 1619D1
BID DATE: WEDNESDAY MAY 6TH, 2026 @ 10:00 AM
ADDENDUM DATE: April 30th, 2026



For additional questions/information regarding this project, send email or RFI's to office@kingarchitects.net.

NOTICE TO BIDDERS:

This Addendum shall be considered part of the Bid Documents (Drawings & Specifications) for the above referenced project and shall be integrated into the final Contract Documents to complete the Work. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their bid on account of this Addendum. It will be construed that each Bidder' Bid is submitted with full knowledge of all modifications and supplemental data specified therein. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This addendum consists of 01 pages which include: Addendum Items (01 pages), and Project Manual pages (00 pages), and Drawing Sheets (00 pages).

GENERAL ITEMS/MODIFICATIONS:

ARCHITECTURAL, GENERAL ITEMS:

1. Delete "Section 03 52 16.13 - Lightweight Insulating Cellular Concrete" in it's entirety from the Project Manual

PROJECT MANUAL ITEMS/MODIFICATIONS:

ARCHITECTURAL PROJECT MANUAL ITEMS:

DRAWING ITEMS/MODIFICATIONS:

ARCHITECTURAL DRAWINGS ITEMS:

PRIOR APPROVALS:

The following are prior approved for bidding. The Manufacturers listed below are approved in name only. Approval does not waive any requirements of the plans and specifications. Shop drawings will be required for final review and approval if specific items under construction. The manufacturers listed must ensure they can meet all requirements of the plans and specifications. Contractor shall ensure that the products used in preparation of his/her proposal and proposed to be used on this project, is equivalent to that specified in appearance, performance, size, installation type, and shape. Any material found to not be equivalent to that specified will be rejected. Prior approval of one manufacturer does not automatically prior approve any subsidiary company, parent company and/or sister company and their associated products.

END OF ADDENDUM NO. 06 ITEMS