

ADDENDUM NO. 1

DILLER ROAD WATERLINE IMPROVEMENTS
ALLEN WATER DISTRICT, ALLEN COUNTY OHIO

Project No. 223873.02

Index of Contents

Addendum No. 1, 2 Item, 2 Pages

January 25, 2024

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Engineer under the Laws of the State of Ohio.

ACCESS ENGINEERING SOLUTIONS



BRUCE
SCHMITZMEIER
PE-00117

BRUCE SCHMITZMEIER
1/25/2024

TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1 to Drawings and Specifications for the Diller Road Waterline Improvements Project Allen Water District, Allen County, Ohio; as prepared by Access Engineering Solutions, Celina, Ohio.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum and acknowledge the receipt of said addendum on the bid forms.

ITEM NO. 1 – Clarification on Stone Bedding Waterline

A. Plan Sheet 5 Water Main Trench Detail

Under Trench Detail Note A – The Structural bedding does not have be natural gravel. Limestone material will be allowed.

ITEM NO. 2 – Clarification on Maintaining Traffic

A. Plan Sheet 3 Maintaining Traffic Note

Add the following text to the Maintaining Traffic Note

One Way traffic will need to be maintained on Diller Road during construction operations. Flaggers or signals will be allowed for traffic control.