

ADDENDUM NO. 1

TERRACE AVENUE & CEDAR STREET IMPROVEMENTS

VILLAGE OF COLDWATER, OHIO

Project No. C25018.4A

Index of Contents

Addendum No. 1, 2 Items, 3 Pages (including attachment)

Attachments

Restraint Table – 1 Page

January 19, 2026

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Engineer under the Laws of the State of Ohio.

ACCESS ENGINEERING SOLUTIONS



TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1 to Drawings and Specifications for the Terrace Avenue & Cedar Street Improvements project, Village of Coldwater, Ohio; as prepared by Access Engineering Solutions, Celina, Ohio.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum and acknowledge the receipt of said addendum on the bid forms.

ITEM NO. 1 – SHEET 5 of the CONSTRUCTION PLANS – FIRE HYDRANTS:

- A. Clarification that the Village will purchase and provide the fire hydrants for this project. The contractor is responsible for purchasing the branch tee, anchor pipe, watch valve/box, necessary piping, etc., and the contractor is to provide all installation.

ITEM NO. 2 – WATERLINE PIPE BELL RESTRAINED JOINTS:

- A. Pipe bell restraints for the waterline joints are required for this project. Requirements are per the attached restrained joint table. A minimum of one pipe bell shall be restrained in each direction of a fitting, regardless of the attached table value. Restraints to be EBBA Iron Series 1500 or similar.

DEFLECTION ANGLE	TYPE OF BEND	PVC Pipe Size									
		2"×3"	4"	6"	8"	10"	12"	14"	16"	18"	20"
11 1/4°	HORZ.	4'	4'	4'	4'	4'	4'	4'	4'	4'	4'
	VERT.	4'	4'	5'	6'	8'	9'	10'	12'	13'	15'
22 1/2°	HORZ.	4'	4'	4'	4'	4'	5'	5'	6'	7'	7'
	VERT.	6'	7'	10'	13'	15'	18'	21'	24'	27'	29'
45°	HORZ.	4'	4'	5'	7'	8'	9'	11'	12'	14'	15'
	VERT.	12'	14'	20'	27'	32'	38'	44'	50'	55'	61'
90°	HORZ.	7'	9'	12'	16'	19'	23'	26'	30'	33'	36'
	VERT.	20'	25'	35'	47'	56'	67'	76'	86'	96'	105'
TEES	RUN	4'	4'	5'	7'	8'	8'	8'	8'	8'	8'
	BRANCH	4'	4'	4'	4'	4'	14'	23'	34'	43'	53'
DEAD ENDS		20'	24'	35'	46'	56'	66'	76'	87'	97'	107'
		Minimum Distance Restrained in Each Direction From Fitting									

RESTRAINED JOINT TABLE - 150 PSI

(BACKHOE EXCAVATION)