

ADDENDUM NO. 1

Baty & Neely Waterline Improvements
Allen Water District, Allen County, OH

Project No. C26073.2A

Index of Contents

Addendum No. 1, 3 Items, 1 Page

Attachments

None

October 23, 2026

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Engineer under the Laws of the State of Ohio.

ACCESS ENGINEERING SOLUTIONS



10-23-2026

TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1 to Drawings and Specifications for the Baty & Neely Waterline Improvements Project, Allen Water District, Allen County, Ohio; as prepared by Access Engineering Solutions, Celina, Ohio.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum and acknowledge the receipt of said addendum on the bid forms.

ITEM NO. 1 – CLARIFICATION – WATERLINE DEPTH

The depth of the proposed waterline is to be 4.5' from top of pipe to the existing ground surface. The water main trench detail on sheet 5 of the construction plans shows this depth correctly. The plan and profile sheets in the construction plans should be corrected from "4' Min Cover" to read "4.5' Min Cover".

ITEM NO. 2 – CLARIFICATION – STORM WATER POLLUTION PREVENTION PLAN (SWP3)

A SWP3 is not anticipated to be needed for this project. If a plan does need to be developed, the cost of the plan will be paid through Bid Item 30 – Project Allowance.

ITEM NO. 3 – CLARIFICATION – MAINTENANCE OF TRAFFIC

A Minimum of one lane of traffic is to be maintained during construction operations. The contractor is to provide traffic control meeting requirements of the Ohio Manual of Uniform Traffic Control Devices.