

ADDENDUM NO. 1

STATE ROUTE 703 WATERLINE REPLACEMENT

CITY OF CELINA,
MERCER COUNTY, OHIO

Project No. C25003.03

Index of Contents

Addendum No. 1, 2 Items, 2 Pages

Attachments

None

February 23, 2026

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Engineer under the Laws of the State of Ohio.

ACCESS ENGINEERING SOLUTIONS



TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1 to Drawings and Specifications for the State Route 703 Waterline Replacement project, City of Celina, Mercer County, Ohio; as prepared by Access Engineering Solutions, Celina, Ohio.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum and acknowledge the receipt of said addendum on the bid forms.

ITEM NO. 1 – WATER MAIN DIRECTIONAL BORE PIPE MATERIAL SPECIFICATION:

- A. Clarification that the directional bore waterline pipe material is to be either C900/RJIB Certa-Lok PVC DR-18 or Fusible C900 PVC DR-18 DIPS pipe. HDPE pipe is not acceptable for this project.

ITEM NO. 2 – SHEET 11 & 12 OF THE CONSTRUCTION PLANS – EXISTING FENCE:

- A. Clarification that any and all costs associated with the removal and replacement of the existing wooden split rail fence (located adjacent to the bike path on Sheets #11 and #12) that may be required to allow for the installation of the waterline should be included in the contractor's price for Bid Item #3 – Clearing and Grubbing (Base Bid B – City of Celina Portion).