

ADDENDUM NO. 1

BROADWAY STREET UTILITY IMPROVEMENTS

VILLAGE OF COVINGTON, OHIO

Project No. 222824.01B

Index of Contents

Addendum No. 1, 3 Item, 1 Page

February 9, 2026

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Engineer under the Laws of the State of Ohio.

ACCESS ENGINEERING SOLUTIONS



*Bruce Schmittmeyer*  
2/9/2026

TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 1 to Drawings and Specifications for the Broadway Street Utility Improvements, Village of Covington, Ohio; as prepared by Access Engineering Solutions, Celina, Ohio.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum and acknowledge the receipt of said addendum on the bid forms.

ITEM NO. 1 – EXISTING ROADWAY CORE INFORMATION - CLARIFICATION

Three pavement cores were done in the project area and the pavement composition was found to be 4 to 6 inches of asphalt over 12 inches of concrete. This should be factored in the unit price for Item 6 – Pavement Removal

ITEM NO. 2 – WATER SERVICE LINE INSTALLATION - CLARIFICATION

The contractor will be allowed to utilize open-cut methods to install water service lines. If this method is used, a three (3) foot wide maximum trench width will be allowed for payment of pavement removal and replacement.

ITEM NO. 3 – COMMERCIAL CONCRETE DRIVE REPLACEMENT

Commercial Concrete Drive replacement is to be 8" in thickness. The bid form indicated 9" Concrete Drive (Commercial).