

Certificate of Water Analysis

7596-B Beth-Bath Pike
Bath, PA 18014
(610) 837-7721 ABE-LABS.com
DEP Lab #48-00108

Sample Number: 21-05269
Report Date: 06/10/21
Version: Initial
Page 1 of 1

Client Business: Wild Blue Group

Client Name: Thom Schiavone

Sample Address:

Source:

Date Collected:

Sampled By:

Well

06/07/21

T. Schiavone

Albrightsville, PA 18210

Sample Location:

Time Collected:

Kitchen

1500

Test	Result	Units	Method	MCL	P/F	QL	Prep Date /Time	Analysis Date
<u>Microbiology</u>								
Total Coliform/100mL*	Absent		SM 9223	0	Pass	1	06/08/21 1600	06/09/21
E. coli/100mL*	Absent		SM 9223	0	Pass	1	06/08/21 1600	06/09/21
<u>Inorganics</u>								
Nitrate*	<2.5	mg/L	Orion ATI 601	10	Pass	2.5		06/09/21
Nitrite*	<0.1	mg/L	SM 4500-NO2-B	1	Pass	0.1		06/09/21
Total Nitrate/Nitrite	<2.5	mg/L		10	Pass			06/09/21

Outsourced Tests^ First Draw Lead

Pass, Report Attached

Results are reported on an "as received" basis.

This report may not be reproduced except in full without the written approval of ABE Laboratories.

Approved by:



Laboratory Supervisor

Approval Date: 06/10/21

Report Notes:

* Tests are covered by ABE Laboratory's scope of accreditation.

^ Tests are subcontracted to a DEP certified laboratory. See attached report(s).

MCL: Maximum Contaminant Level based on EPA standards.

QL: Quantitation Limit is the lowest concentration measurable for a specific test.

END OF REPORT



M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Certificate of Analysis

Laboratory No.: 2120332

Reported: 06/10/21

Lab Contact: Paulina Laudan Webb

Attention: Greg Ness
Reported To: ABE Lab
7596B Beth-Bath Pike
Bath, PA 18014

Project: Homeowner Metals (NON-DEP)

Lab ID: 2120332-08 **Collected By:** Client **Sampled:** 06/07/21 15:00 **Received:** 06/09/21 12:46
Sample Desc: 21-05269 261 Brittany Drive **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max	Pass/Fail
Total Metals									
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	06/09/21		MPB	N/A 0.015	*

Notes and Definitions

Pass Result less than EPA maximum contaminant level.

Fail Result greater than EPA maximum contaminant level.

* Maximum contaminant limits of 0.005 mg/l for Lead and 1.0 mg/l for Copper apply to bottled/purchased water. Averaged maximum contaminant limits of 0.015 mg/l for Lead and 1.3 mg/l for Copper apply to public water supplies.

Preparation Methods

Specific Method	Preparation Method	Prepared Date	Prepared By
2120332-08			
EPA 200.8 Rev 5.4	EPA 200.8 Rev 5.4	06/09/2021	MPB



107 Angelica Street ○ Reading, PA 19611 ○ www.mjreider.com ○ (610) 374-5129 ○ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261), NY(12094)

Certificate of Water Analysis

7596-B Beth-Bath Pike
Bath, PA 18014
(610) 837-7721 ABE-LABS.com
DEP Lab #48-00108

Sample Number: 21-05269
Report Date: 06/10/21
Version: Initial
Page 1 of 1

Client Business: Wild Blue Group

Client Name: Thom Schiavone

Sample Address:

Source:

Date Collected:

Sampled By:

261 Brittany Drive
Albrightsville, PA 18210

Well

06/07/21

T. Schiavone

Sample Location:
Kitchen


Time Collected:
1500

Test	Result	Units	Method	MCL	P/F	QL	Analysis Date
<u>Inorganics</u>							
pH*	7.0		SM 4500-H+ B	6.5-8.5	Pass	4.0-10.0	106/08/21
Total Solids	136	mg/L	SM 2540 C	500	Pass	20	06/09/21
Hardness	1.7	gpg	Manver 2 Buret			0.6	06/10/21
Iron	<0.02	mg/L	1,10 Phenanthroline	0.3	Pass	0.02	06/10/21
Manganese	0.02	mg/L	PAN	0.05	Pass	0.01	06/10/21

Results are reported on an "as received" basis.

This report may not be reproduced except in full without the written approval of ABE Laboratories.

Approved by:



Laboratory Supervisor

Approval Date: 06/10/21

Report Notes:

* Tests are covered by ABE Laboratory's scope of accreditation.

^ Tests are subcontracted to a DEP certified laboratory. See attached report(s).

MCL: Maximum Contaminant Level based on EPA standards.

QL: Quantitation Limit is the lowest concentration measurable for a specific test.

END OF REPORT