

1302 Madison Avenue
Suite 200
Dunmore, PA 18509



DEP LAB ID#: 35-04831

Markey Water Services

PO Box 928
Hamlin, PA 18427
570-689-5660

Chain of Custody Number	Sample Type	Project ID	Sample Date/Time	Accession Date
3943179	S	TASD Primary Special	09/01/2026 07:50 AM	09/01/2026

Laboratory Information:

Incubation: 9/1/26 16:33

Method	Test	Result	Unit	PQL	Analyst	Analysis Date/Time	Lab ID	Description
Colitag (Modified)	Total Coliform (DW)	Absent	cfu/100mL	0	TC	09/02/2026 02:24 PM	9-26W64562	753 - Room 24 Sink
Colitag (Modified)	Total Coliform (DW)	Absent	cfu/100mL	0	TC	09/02/2026 02:24 PM	9-26W64563	001 Raw
Colitag (Modified)	E. coli (DW)	Absent	cfu/100mL	0	TC	09/02/2026 02:24 PM	9-26W64563	001 Raw

Date: 09/02/2026

Reviewed By:

A handwritten signature in black ink, appearing to read "Michael J. Coyer", is written over a horizontal line.

Michael J. Coyer, Ph.D., F-ABFT