

RE: roofing questions

From: Davis, Steven G (steven.davis1@okc.gov)

To: vgcok@yahoo.com

Date: Tuesday, April 7, 2020, 12:09 PM CDT

Mr. Weir

In Table R301.2(1) for Ice Barrier underlayment required the answer is yes. The 24" warm wall requirement for ice and water shield is being enforced.

Thank you,

Steve Davis

Chief Building Inspector, OKC

(405)297-2351

From: Gerry Weir <vgcok@yahoo.com>
Sent: Tuesday, April 7, 2020 11:49 AM
To: Davis, Steven G <steven.davis1@okc.gov>
Subject: Re: roofing questions

Please supply a letter that states the OKC requirement regarding the table and warm wall ice/water barrier, since you can't supply your table. Or a statement like you did yesterday over the phone that OKC requires the 24" warm wall requirement for re-roofing.

Thanks,

Gerry Weir

Village General Contracting

405-795-7663

On Tuesday, April 7, 2020, 11:40:52 AM CDT, Davis, Steven G <steven.davis1@okc.gov> wrote:

Mr. Weir

Because of copy right laws I cannot forward anything from the IRC.

Steve Davis

Chief Building Inspector, OKC

CONFIDENTIALITY NOTE: This e-mail message and any attachments are intended solely for the person to which it is addressed and may contain privileged and confidential information protected by law. If you have received this communication in error, please notify the sender immediately by telephone or e-mail, destroy this message and delete any copies held in your electronic files. Unauthorized use and/or re-disclosure may subject you to penalties under applicable state and federal laws.

CONFIDENTIALITY NOTE: This e-mail message and any attachments are intended solely for the person to which it is addressed and may contain privileged and confidential information protected by law. If you have received this communication in error, please notify the sender immediately by telephone or e-mail, destroy this message and delete any copies held in your electronic files. Unauthorized use and/or re-disclosure may subject you to penalties under applicable state and federal laws.