


BALLABS CERTIFIED TEST REPORT NO.: 20093.0 DATE 10/30/17  
PREPARED FOR: SCIENTIFIC LIGHTING PRODUCTS, INC - FENTON, MO  
DESCRIPTION: 4-44 LED 22"ARRAYS 8'EXTRUDED SURFACE MNT LUMINAIRE  
WHITE FLAT REFL IN ACRYLIC HOUSING w/WHITE DIFFUSER  
PHILIPS XITANIUM DRIVER #XI075C200V054YPT2 w/27K RESISTOR  
CATALOG NBR: PRF-S1-8-LZH-40-U  
LAMP TYPE : FORTIMO LED LINE 2FT 4000LM 840 1R LV2

## CANDLEPOWER DISTRIBUTION

VERT ANG	0	22.5	45	67.5	90	ZONAL LUMENS
0	2546.	2546.	2546.	2546.	2546.	
5	2540.	2540.	2542.	2545.	2546.	242.7
10	2501.	2503.	2511.	2521.	2523.	
15	2348.	2351.	2371.	2390.	2401.	672.3
20	2213.	2223.	2255.	2289.	2319.	
25	2155.	2172.	2216.	2263.	2291.	1026.9
30	1987.	2011.	2068.	2127.	2151.	
35	1821.	1851.	1928.	2007.	2026.	1210.5
40	1617.	1654.	1752.	1850.	1872.	
45	1522.	1566.	1695.	1816.	1866.	1310.9
50	1333.	1382.	1525.	1656.	1725.	
55	1111.	1167.	1316.	1450.	1525.	1177.7
60	907.	975.	1128.	1260.	1318.	
65	744.	825.	1001.	1146.	1185.	976.8
70	548.	648.	847.	990.	1018.	
75	350.	472.	677.	814.	849.	677.6
80	184.	340.	559.	698.	755.	
85	60.	233.	452.	594.	658.	446.9
90	7.	137.	325.	447.	496.	
95	0.	89.	257.	360.	393.	246.2
100	0.	50.	188.	276.	309.	
105	0.	22.	137.	213.	241.	130.3
110	0.	5.	98.	167.	189.	
115	0.	0.	53.	120.	140.	60.3
120	0.	0.	20.	80.	99.	
125	0.	0.	13.	37.	53.	17.0
130	0.	0.	0.	16.	18.	
135	0.	0.	0.	0.	15.	1.4
140	0.	0.	0.	0.	0.	
145	0.	0.	0.	0.	0.	.0
150	0.	0.	0.	0.	0.	
155	0.	0.	0.	0.	0.	.0
160	0.	0.	0.	0.	0.	
165	0.	0.	0.	0.	0.	.0
170	0.	0.	0.	0.	0.	
175	0.	0.	0.	0.	0.	.0
180	0.	0.	0.	0.	0.	



**NVLAP**<sup>®</sup>  
TESTING

NVLAP LAB CODE 200921-0

## LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	1942.	NA.	23.7	90-120	437.	NA.	5.3
0- 40	3152.	NA.	38.5	90-130	454.	NA.	5.5
0- 60	5641.	NA.	68.8	90-150	455.	NA.	5.6
0- 90	7742.	NA.	94.4	90-180	455.	NA.	5.6
TOTAL LUMINAIRE = 0-180					8197.	NA.	100.0

IES SPACING CRITERIA: END= 1.2 DIAGONAL = 1.2 CROSS= 1.3

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20093.0 DATE 10/30/17  
 PREPARED FOR: SCIENTIFIC LIGHTING PRODUCTS, INC - FENTON, MO  
 DESCRIPTION: 4-44 LED 22"ARRAYS 8'EXTRUDED SURFACE MNT LUMINAIRE  
 WHITE FLAT REFL IN ACRYLIC HOUSING w/WHITE DIFFUSER  
 PHILIPS XITANIUM DRIVER #XI075C200V054YPT2 w/27K RESISTOR  
 CATALOG NBR: PRF-S1-8-LZH-40-U  
 LAMP TYPE : FORTIMO LED LINE 2FT 4000LM 840 1R LV2  
 \*\*\*\*\*

LUMINANCES-CD/SQ-M			
HORIZONTAL ANGLE			
VERT	0	45	90
ANGLE			
45	14774.	11346.	12496.
55	13294.	9590.	11111.
65	12085.	8276.	9792.
75	9280.	6697.	8408.
85	4731.	5796.	8431.

\*\*MAXIMUM BRIGHTNESSES NOT MEASURED\*\*

\*\*\*\*\*

#### ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30				.10				.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00			
RCR																					
0	1.18	1.18	1.18	1.18	1.14	1.14	1.14	1.14	1.08	1.08	1.08	1.02	1.02	1.02	.97	.97	.97	.94			
1	1.07	1.01	.97	.93	1.03	.99	.94	.91	.93	.90	.87	.88	.86	.83	.84	.82	.80	.77			
2	.97	.88	.81	.75	.94	.86	.79	.74	.81	.76	.71	.77	.73	.69	.74	.70	.67	.64			
3	.89	.78	.70	.63	.86	.76	.68	.62	.72	.66	.60	.69	.63	.58	.65	.61	.57	.54			
4	.81	.69	.60	.53	.78	.67	.59	.53	.64	.57	.51	.61	.55	.50	.58	.53	.49	.46			
5	.74	.61	.52	.45	.71	.59	.51	.44	.57	.49	.43	.54	.48	.42	.52	.46	.41	.39			
6	.68	.54	.45	.39	.66	.53	.45	.38	.51	.43	.38	.48	.42	.37	.46	.41	.36	.34			
7	.63	.49	.40	.34	.60	.48	.39	.33	.46	.38	.33	.44	.37	.32	.42	.36	.31	.29			
8	.58	.44	.35	.29	.56	.43	.35	.29	.41	.34	.28	.39	.33	.28	.38	.32	.27	.25			
9	.53	.39	.31	.25	.51	.38	.30	.25	.37	.30	.24	.35	.29	.24	.34	.28	.24	.22			
10	.49	.36	.28	.22	.48	.35	.27	.22	.34	.26	.22	.32	.26	.21	.31	.25	.21	.19			

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20093.0 DATE 10/30/17  
PREPARED FOR: SCIENTIFIC LIGHTING PRODUCTS, INC - FENTON, MO  
DESCRIPTION: 4-44 LED 22"ARRAYS 8'EXTRUDED SURFACE MNT LUMINAIRE  
WHITE FLAT REFL IN ACRYLIC HOUSING w/WHITE DIFFUSER  
PHILIPS XITANIUM DRIVER #XI075C200V054YPT2 w/27K RESISTOR  
CATALOG NBR: PRF-S1-8-LZH-40-U  
LAMP TYPE : FORTIMO LED LINE 2FT 4000LM 840 1R LV2

\*\*\*\*\*

ELECTRICAL CHARACTERISTICS 120.06V .5858A 70.150W

LUMINOUS EFFICACY (LUMENS / WATTS) = 116.9

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS  
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08

