

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Langley PWA Did Not Meet Treatment Requirements**

Our water system recently violated a drinking water requirement. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct the situation.

We routinely monitor your water for turbidity (cloudiness). This tells us whether we are effectively filtering the water supply. When there are high levels of turbidity, there is an increased chance that the water may contain disease-causing organisms.

We routinely monitor your water for disinfectant residual at the point of entry to the distribution system and in the distribution system. This tells us whether we are effectively disinfecting the water supply. If the amount of disinfectant is too low, organisms could grow in the pipes. The following sample sites failed to maintain adequate free chlorine residuals of 1.0 mg/L:

Sample Site	Monitoring Period	Number of Results Below Standard
TP001- Langley WTP	June 2025	3

**What should I do?**

There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking the water.

**What does this mean?**

This is not an emergency. If it had been, you would have been notified within 24 hours.

*Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.*

These symptoms, however, are not caused only by organisms in drinking water, but also by other factors. If you experience any of these symptoms and they persist, you may want to seek medical advice.

**CORRECTIVE ACTION**

**What happened? What is being done? When will the violation be resolved?**

CL17 messed up. WAS showing the wrong reading. But nothing was really wrong. Omni came out and fixed it.

For more information, please contact: William Evans. (918) 937-3223

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Langley PWA    PWSID#: OK1021604    NOV #: P-1021604-25-1

Date Distributed: 8.14.25