

## **AETA Parking Lot SAUT25-26/07**

### **Questions & Answers**

1. Question: On a portion of the North side of the existing parking area there is no existing gravel (approximately 2500SF), do you want us to price it all as just being graded with approximately 2" of sb2 overlay and include a unit price for cut/fill? Or should we assume a certain amount of cut, fill, and gravel for that area?

Answer: We will show 6" of gravel to be put under the parking without existing gravel. The new topography lines should show how much cut/fill will be needed.