

NORWECO Aeration - Operation and Maintenance

1. Aeration sewage treatment systems are issued an annual permit.
2. A service contract with a registered service contractor or the health department is required.
3. An annual inspection is required by a registered service contractor or a trained homeowner. Submit a copy of the inspection report to the health department within sixty days of the inspection.
4. The permit requires the tank to be pumped every eight years, at a minimum. Some tanks may benefit from more frequent pumping, based on the size of the tank and the number of people.
5. The ultraviolet disinfection unit requires maintenance every six months. This involves cleaning the quartz sleeve and ensuring the uv light is working.
6. Follow the manufactures recommendations for the aerator.
7. Test the alarm every six months or less.

For more detailed information visit NORWECO's website: <https://www.norweco.com>

