

<b>Potential Contamination Source</b>	<b>Minimum separation distance</b>
House / building	10'
Deck / Porch (no foundation)	5'
Lot lines/Easements	10'
Existing private well	10'
Existing public well	EPA requirement
Properly sealed well	5'
Well of unknown/unregulated/unpermitted well	50'
Road right of way / utility easements	10'
Road driving surface	25'
Driveway / parking lot	5'
Watertight sewer or drain	10'
Sewage Tank, absorption fields, watertight privie, gray water	50'
Leaching privie, leaching pit, dry or drainage well	100'
<b>Geothermal</b>	
Vetical open loop from a well with a well log on file	25'
Vertical/Horizontal with propylene glycol	25'
Vertical/Horizontal withOUT propylene glycol	50'
Vertical/horizontal of unknown/undocumented construction	50'
Permanent bodies of water: Lake, pond, river	25'
Intermittent flows of storm water, not in the road right of way	15'
Bulk salt storage/piles	100'
Natural gas / propane above or below ground	20'
Fuel/diesel/gas tanks <1100 gallons, fuel operated well pump	50'
Fuel/oil/diesel >1100 gallons	300'
Oil/gas wells	100'
Waste/composting facility (open or closed)	1000'
Construction/demolition debris	500'
Surface application/storage area of septage/manure, waste plant	300'
Animal pens (no grass)/stables/manure piles/dry stack buildings	50'
In a pasture fencing is required around well	5'
<b>Animal Feeding Facilities (AFF)</b>	
Major facility/large facility/medium facility	300'
AFF (other major/large/medium)	150'