

CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

McMurrich-Monteith Township Fire Department

F.S. Sprucedale (7)

Date Test Passed: August 30, 2023

Residential and Industrial Certification (7)

Flow Achieved: 420 I.G.P.M Liters Per Min: 1911
Two (2) Hour Test Time

Signed: Melissa Rose
Melissa Rose - Principal

This Certificate is valid for 5 years and expires August 31, 2028