



CEMENTOS ALFA, S.A.

PLANT: MATAPORQUERA

ER Certificate: ER-0572/1998



TECHNICAL CHARACTERISTICS CERTIFICATE

Cement

CEM II/A-L 42.5 R BS-EN 197-1

**N: 015/002144
CE: 0099/CPR/A33/1061**

Period

May, 2025

TESTS	Results Average Value	Standard Spec. EN/UNE
Chemical Characteristics		
Loss on Ignition	%	
Insoluble Residue	%	
Sulphates (SO ₃)	%	< 4,0
Chlorides	%	< 0,10
Physical and Mechanical Characteristics		
Normal Consistency Water	%	29,5
Initial Setting Time	min	188
Final Setting Time	min	237
Soundness Le Chatelier	mm	0,7
Specific Surface (Blaine)	cm ² /g	4474
Compressive Strength at 2 days	MPa	
• Monthly average	30,8	> 20,0
• Cumulative average (06/2024 - 05/2025)	31,3	> 20,0
• Cumulative Std. Dev. (06/2024 - 05/2025)	1,7	
Compressive Strength at 28 days	MPa	
• Monthly average	54,6	42,5 - 62,5
• Cumulative average (06/2024 - 05/2025)	56,6	42,5 - 62,5
• Cumulative Std. Dev. (06/2024 - 05/2025)	1,8	
Additional Characteristics		
C3A *	(%)	7,0
Alkali Equivalent	(%)	0,80

* Corresponding to clinker composition

This document doesn't imply that any amount of cement has been supplied by the Company

Barrio la Estación, s/n.
39410 Mataporquera (Cantabria)
Tel. 942 770 058
Fax 942 770 243
info@alfainforma.com
www.valderrivas.es

Chief of Quality Control

