



WATER & WASTEWATER REPORT

CITY OF ALBA

September 2025

CONTACT INFO

SHAWN NEWLAND

Public Works Director

☎ 903-850-3475

✉ Albawd@peoplescom.net



RANDALL BOHANNAN

Water & Wastewater
Operator

☎ 903-850-3408

✉ Albawd@peoplescom.net



Alba ★

TX

© Copyright 2025 PeoplesCom.net



WATER DEPARTMENT REPORT

- The Water Department on 9-10-25 repaired a 6" leak on Quitman St. Ken and Micheal Anglin for the assistance
- Water treated and pumped to distribution system 2.179265 Gal
- Flushing of the dead-end mains used 14,700 gallons of water resulting in an average residual of 1.42 at flushing locations.
- We replaced a 2" valve on Collage St. that feeds the Government apartments
- Shawn Newland was off work September due to family illnesses.
- John Deere tractor is in shop for major repairs.
- Our TCEQ Microbial Analysis Results met all accreditation requirements.
- Began purchasing hand and battery-operated hand tools.



WASTEWATER DEPARTMENT REPORT

- This month's DMR should reflect no violations.
- Street repairs were made across town in areas.
- Mowing right-of way and easements.
- Mowing has been continuous.
- Replacement of cleanout lids through the city sewer system in September when found broken.
- Sewer treatment 1.1MG