



# WATER & WASTEWATER REPORT

CITY OF ALBA

February 2026

## CONTACT INFO

**SHAWN  
NEWLAND**



Public Works Director

☎ 903-850-3475

✉ Albawd@peoplescom.net

**RANDALL  
BOHANNAN**



Water & Wastewater  
Operator

☎ 903-850-3408

✉ Albawd@peoplescom.net

*Alba* ★

## WATER DEPARTMENT REPORT

**WATER SYSTEM SUMMARY:** February production stabilized following elevated usage in late January. Daily production generally ranged between 70,000-90,000 gallons per day, returning to normal operating levels. On February 12, 2026, TCEQ conducted an inspection and identified a North Well booster pump seal issue. On February 22, 2026, Booster Pump #1 was removed from service for inspection, and a failed impeller was identified. Corrective action is underway. Residuals throughout the system were maintained within compliance limits, and system pressure remained stable near 60 psi at the elevated tank. End-of-line flushing and distribution monitoring were conducted regularly to maintain disinfectant levels and water quality.

## WASTEWATER DEPARTMENT REPORT

**WASTEWATER SYSTEM SUMMARY:** Rain events mid-month significantly increased inflow and infiltration (I&I). On February 14, 2026, following approximately 2 inches of rainfall, an unauthorized discharge occurred at the ALS Lift Station due to pump priming failure and debris obstruction. A pump truck was called, the station was pumped down, debris was removed, and cleanup was completed. Elevated lagoon levels and lift station runtimes were monitored closely over subsequent days. By February 21-23, flows returned to normal operating range. Chlorine residuals were maintained within permit requirements. SPL weekly effluent reports were reviewed against permit limits, and all documentation remained current.