

# Accessibility Report


## Image Gallery (max 24 images shown)



Arrival and parking




Reception and entry




General Areas




General Areas



Wheelchair Accessible Room



Wheelchair Accessible Room



Wheelchair Accessible Room




Wheelchair Accessible Room




Easy Access Accommodation




Easy Access Accommodation



Restaurants




Restaurants



Swimming Pool



Swimming Pool



Day Spa

## Form Responses

Question	Answer	Detail
<b>Accessible Accommodation</b>		
Is there wheelchair accessible accommodation?	Yes	
Wheelchair Accessible Rooms		2
Is there easy access accommodation?	Yes	
Easy Access Rooms		2
<b>Arrival and Parking</b>		
Guest parking	Yes	
Undercover clearance	No	
Drop-off point	Yes	drop off point in the front of entrance
Step free entry to building	Yes	
<b>Reception and Entry</b>		
Reception	Yes	24 hours
Step free entry to Reception	Yes	
Low height service counter	Yes	
Seating options	Yes	Sofa chair is available

Question	Answer	Detail
Free Wi-Fi	Yes	
<b>General Areas</b>		
Walkways	Yes	
Step free paths	Yes	
Steepest Ramp	Yes	1 : 6
Accessible toilets	No	There is a step at the toilet door
<b>Elevators</b>		
Elevators	Yes	
Door Width		770mm
Circulation space		1150mm x 1100mm
<b>Wheelchair Accessible Room</b>		
Step free path of travel to room	Yes	
Ramp Gradient	Yes	1 : 6
Narrow point of ramp		980mm
Handrails on ramp - Side		None
Door Width		900mm
Outside door circulation space		The circulation space outside the doorway is 2000-2500 mm
Door and handle style		Yes, standard handle
<b>Wheelchair Accessible Bathroom</b>		
Bathroom door width		900mm
Toilet with grabrails		Yes
Toilet Height		400mm
Side clearance to toilet		600mm
Basin clearance underneath		570mm
Mirror over basin height		Yes
Roll in shower size		Yes
Shower seating	Yes	Build in the shower
Handheld Showerhead	Yes	
<b>Bedding</b>		
Bed height		660mm
Clearance under bed		No
Clearance around bed		Yes
<b>Furniture &amp; Fittings</b>		

Question	Answer	Detail
Switches and controls height		1360mm
Light controls reach from bed		Yes
Furniture moveable		Yes
Clothes storage access		Yes
Curtains / Blinds operation		Yes
<b>Kitchen and food</b>		
Cooking facilities	Yes	Only tea and coffee facility
Bench height		760mm
Appliances location		above the bench
Crockery and utensils location		no utensils
<b>Balcony / Courtyard</b>		
Balcony or courtyard	Yes	
Access to balcony or courtyard	Yes	no step
Door Width		1540mm
<b>Easy Access Accomodation</b>		
Step Free Path of travel	Yes	
Ramp Gradient	Yes	1 : 6
Narrow point of ramp		980mm
Handrails on ramp - Side		None
<b>Bathroom</b>		
Toilet with grabrails	No	
Shower details	Yes	
Shower chair	Yes	
Shower grabrail	Yes	
Hand held showerhead	Yes	
<b>Restaurants</b>		
Cafe or restaurant	Yes	
Step free access	Yes	
Ramp Gradient	Yes	1 : 6
Narrow point of ramp		980mm
Handrails		None
Accessible Toilet	No	there is a step to the toilet
Seating options		yes
Service counters		no

Question	Answer	Detail
Table Service	No	
<b>Swimming Pool</b>		
Are there swimming pools?	Yes	
Number of Swimming Pool		2
Pool Name		Azaa Pool
Ramped or level access	No	
Hoist	No	
Stairs	Yes	3 steps
Handrails on steps		Middle
<b>Day Spa</b>		
Day Spa	Yes	
Step free access	Yes	
Ramp gradient	Yes	1 : 5
Narrow point on ramp		1400mm
Handrails on ramp - Side		None
Entry door width		1400mm
Outside door circulation space		5000mm x 6000mm
Door and handle style	Yes	push to open
Adjustable Treatment Tables	No	fixed height
In Room Treatment Options	No	