



Compliance Statement

Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

RIT Tech Identification: P/N R3719XXP
Cat. 7, Overall Braid Screened Cable with Foil Screened Twisted Pairs
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable

RIT Tech (Intelligence Solutions) Ltd
20 Atir Yeda St.,
Kfar Saba 4464315 Israel

Compliance Statement No. 0019-3P-2026-429

This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by FORCE Technology under the 3P maintenance programme and complies with the Category 7 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-E:2024, the requirements of CENELEC EN 50288-4-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to EN 60332-1-2 / IEC 60332-1-2, EN 61034-2 / IEC 61034-2 and EN 60754-2 / IEC 60754-2. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 12 March 2027.


Hoersholm, 12 March 2026



Peter Freiberg Kaas
Senior Specialist, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
<https://www.3ptest.dk/>

Hoersholm, 12 March 2026



Lars Lindskov Pedersen
Senior Team Leader, Test Manager