



# Compliance Statement

## IEC 60332-3-24:2018

### Copper Communication Cable

**Part no. R2715XXP**  
**100  $\Omega$ , 4 Twisted Pairs, 23 AWG,**  
**Overall Braid Screened Cable with Foil Screened Twisted Pairs**

**RIT Tech (Intelligence Solutions) LTD.,**  
**20 Atir Yeda St., 4464315 Kfar Saba,**  
**Israel**

***Compliance Statement No. 0473-3P-1230825***

*This type of Copper Communication Cable has been tested by 3P Third Party Testing and complies with IEC 60332-3-24:2018 – “Test for vertical flame spread of vertically-mounted bunched wires or cables – Category C”. The tested cable is part of a 3P maintenance test program, with continuous verification of the fire performance. The Compliance Statement is valid until 25 October 2025.*


*Cable Identification:* R2715XXP

*Cable Marking:* RIT R2715XXP CATEGORY 7A SHIELDED CABLE 100 OHM 4xF(2x23AWG) S/FTP  
LSZH IEC60332-3-22/24 "METER AND BATCH MARKING"

*Cable Description:* 100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Overall Braid Screened Cable with Foil Screened Twisted Pairs

*Cable Dimensions:* OD: 7.5 mm

Hoersholm, 25 October 2023

  
Peter Freiberg Kaas  
Test Responsible

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

*Independent Testing - For End User Confidence*

Hoersholm, 25 October 2023

  
Jens Rytter Petersen  
General Manager