

Sewer Board Meeting Minutes
July 28,2026

Mayor and Council Present:

Garland Breeden, Melinda Miller, Ricky Pastor, Leah Green, Stevie Smith, Chris Deloach & Caleb Story

Absent: None

City Attorney Present: Kirk Vandivort

Sewer Manager Present: Chad Morrow

City Recorder Present: Shari Wright

Meeting Called to Order at 5:30pm by Mayor Garland Breeden.

- 112 martin street controller hung open
- 518 Lewis Lane Blockage in service line. Jetted line out
- 106 Martin Street C and V had water in it
- 3934 Hwy 47 pump was replaced
- Dollar Store Filter clogged.
- 3924 Hwy 47 North pump not working
- 224 Park Circle Replaced valve and controller sump full
- 3174 Vanleer Hwy Controller hung open
- Charlotte Middle School. Obstruction under valve
- Dickson County Jail Controller hung open.
- 3900 Hwy 47 low level float hung. False alarm
- 216 Park Circle C and V replaced
- 3158 Vanleer Hwy Sewer Controller hung open
- 117 Cedarview Replaced controller. Controlling surging3155 Vanleer Hwy Controller hung open
- Church on Dotson St Controller hung open pumps Sewer pump #1 impeller will be delivered mid-August
- Sewer pump #2 will be took apart and gone through after installation of pump #1 Equipment
- Truck #1 using 1.5 quarts of oil every 2 tanks of gas
- Ton truck using excessive amounts of oil. Seal on motor is out Replaced 2 lines on Backhoe
- Replaced belt on f3680Mayor Breeden motioned to adjourn the meeting and Chad Morrow seconds. Ayes: All

Approved:

Chad Morrow, Wastewater Operator

Date: _____

Mayor Garland Breeden