

Sewer Board Meeting Minutes
June 23,2026

Mayor and Council Present:

Garland Breeden, Melinda Miller, Ricky Pastor, Leah Green, Stevie Smith and Chris Deloach

Absent: Caleb Story

City Attorney Present: Kirk Vandivort (Jennifer Foster filling in)

Sewer Manager Present: Chad Morrow

City Recorder Present: Shari Wright

Meeting Called to Order at 5:30pm by Mayor Garland Breeden.

- 106 Martin Street Replaced controller. Low vacuum (debris in controller)
- 3934 Hwy 47 Pump out. Replaced with 30 gpm for temporary use.
- 3934 Hwy 47 Replaced 10 gpm pump
- 3934 Hwy 47 line came off the Sewer pump. High level alarm
- 3675 Hwy 47 Replaced 10 gpm pump
- 3376 Hwy 48. Excavators broke 2 inch mainline.
- 137 Highschool Street. The controller malfunctioned. Replaced.

Repairs/Upgrades/Maintenance

- 105 Picnic Drive. Replaced the old tank with a new Flovac tank. The old tank was leaking water and lower than the surrounding ground.
- Vacuum pump is completed and stored at the Lions Club for a backup pump.
- Sewer pump #1 is still down. Waiting on the impeller to ship before we can reassemble.
- Vacuum Pump #1 Exhaust filter Cracked causing excess use of oil. Pump ran hot burnt exhaust filters. (Replaced the filters. New oil. Operating normal now)
- Changed from Shell Tellus 32 oil to ISO 100 oil for vacuum pumps
- Oil changed in pump #1. New exhaust filters installed. New oil sight glass installed.
- Cleaned both radiators on vacuum pumps
- Replaced Batteries on Generator 6-12-2026

CED hours

- Continuing education hours were approved for Wastewater license
- Need to get 6 hours for Collections license

Trucks

- Changed oil Truck #2

Mayor Breeden motioned to adjourn the meeting and Chad Morrow seconds. Ayes: All

Approved:

Chad Morrow, Wastewater Operator

Date: _____

Mayor Garland Breeden