

Sewer Board Meeting Minutes

May 26,2026

Mayor and Council Present:

Garland Breedon, Melinda Miller, Ricky Pastor, Leah Green, Stevie Smith and Chris Deloach

Absent: Caleb Story

City Attorney Present: Kirk Vandivort

Sewer Manager Present: Chad Morrow

City Recorder Present: Shari Wright

Meeting Called to Order at 5:30pm by Mayor Garland Breedon.

● **Sewer issues**

- 721 Spring St. Replaced controller. Low Vacuum dialer call out
- 112 Phillips Debris hung under valve. Low Vacuum call out
- Car wash. Complaint of sewer smell. Discharge pipe on pump #1 disconnected from main line. Churning the water causing a strong odor.
- 767 Spring St., tank filled with water. Customer stated toilets were gurgling. Surge suppressor broke. Causing controller not to fire.
- 123 Todd Street. Customer complaint. Sewer not going down in toilet. Valve had been turned off inside tank.
- 3032 Vanleer Hwy . Replaced controller
- Dickson county jail. Replace controller. Timing not working properly causing hours on the vacuum to increase
- 3118 Vanleer Hwy replace controller.
- 108 Lynn Lane. Low vacuum replaced controller
- 3025 Vanleer Hwy Replaced controller and valve. Low vacuum
- 3928 Hwy 47 customer complaint alarm going off. Pump failed and was replaced with a new pump
- Don Chuys. Sewer over flow. Reported to the state. Grease had blocked a fitting in the sewer main line. (checked FOG records tanks are being pumped regularly. Recommended looking into upsizing Grease trap. The restaurant has grown a lot since the original equipment was installed.)
- 5-18 vacuum pump hours increased over the weekend. We checked every sewer pot on the vacuum system. Found many issues with controllers firing to long and a couple of valves hanging open. Hours have dropped since it was completed.
- 3155 Vanleer Hwy Replaced controller timer wouldn't adjust down
- Dickson county jail. Readjusted timer on controller to lower the time the valve in open when fired

● **Spray fields**

- Several of the spray heads that were reworked are getting hung in one position and not freely rotating.
- Spray heads that have a pvc stand pipe need to be replaced with metal due to pipes not being rigid enough to allow the spray head to spin.
- Aerator 2-2 has kicked the main breaker inside the shop. Will be addressed
- Fence has multiple areas that needs to be repaired
- Bush hogged some of the areas with weeds and thistles. Bush hogged all the sage grass.

● **Reports**

- 2 Ecoli test will be run this quarter. During the first quarter I failed to send off an Ecoli test. The state has been notified of this incident.

● **Pumps**

- Vacuum pump at TN tool is ready for pickup.
- Sewer pump #1 seals have been installed. Waiting for impeller.
- Irrigation pump #2 at sewer plant still not operating at full capacity. (plan on pulling it when sewer pump is completed)

- Wastewater license
 - CED hours have been completed for Wastewater plant license.
 - Need 6 CED hours for my collections license.

Mayor Breeden motioned to adjourn the meeting and Chad Morrow seconds. Ayes: All

Approved:

Chad Morrow, Wastewater Operator

Mayor Garland Breeden

Date: _____