

Sewer Board Meeting Agenda

July 28, 2026

Sewer issues

- 112 Martin Street controller hung open
- 518 Lewis Lane Blockage in service line. Jetted line out
- 106 Martin Street C and V had water in it
- 3934 Hwy 47 pump was replaced
- Dollar Store Filter clogged.
- 3924 Hwy 47 North pump not working
- 224 Park Circle Replaced valve and controller sump full
- 3174 Vanleer Hwy Controller hung open
- Charlotte Middle School. Obstruction under valve
- Dickson County Jail Controller hung open.
- 3900 Hwy 47 low level float hung. False alarm
- 216 Park Circle C and V replaced
- 3158 Vanleer Hwy Sewer Controller hung open
- 117 Cedarview Replaced controller. Controlling surging
- 3155 Vanleer Hwy Controller hung open
- Church on Dotson St Controller hung open

Pumps

- Sewer pump #1 impeller will be delivered mid-August
- Sewer pump #2 will be taken apart and gone through after installation of pump #1

Equipment

- Truck #1 using 1.5 quarts of oil every 2 tanks of gas
- Ton truck using excessive amounts of oil. Seal on motor is out
- Replaced 2 lines on Backhoe
- Replaced belt on f3680