

## **Sewer Board Meeting Agenda - May 26, 2026**

- Sewer issues
  - 721 Spring st. Replaced controller. Low Vacuum dialer call out
  - 112 Phillips Debris hung under valve. Low Vacuum call out
  - Car wash. Complaint of sewer smell. Discharge pipe on pump #1 disconnected from main line. Churning the water causing a strong odor.
  - 767 Spring st. Tank filled with water. Customer stated toilets were gurgling. Surge suppressor broke. Causing controller not to fire.
  - 123 Todd Sreet. Customer complaint. Sewer not going down in toilet. Valve had been turned off inside tank.
  - 3032 vanleer hwy . Replaced controller
  - Dickson county jail. Replace controller. Timing not working properly causing hours on the vacuum to increase
  - 3118 Vanleer hwy replace controller.
  - 108 lynn lane. Low vacuum replaced controller
  - 3025 Vanleer hwy Replaced controller and valve. Low vacuum
  - 3928 Hwy 47 customer complaint alarm going off. Pump failed and was replaced with a new pump
  - Don chuys. Sewer over flow. Reported to The state. Grease had blocked a fitting in the sewer main line. ( checked FOG records tanks are being pumped regularly. Recommended looking into upsizing Grease trap. The restaurant has grown a lot since the original equipment was installed.)
  - 5-18 vacuum pump hours increased over the weekend. We checked every sewer pot on the vacuum system. Found many issues with controllers firing to long and a couple ov valves hanging open. Hours have dropped since it was completed.
  - 3155 Vanleer hwy Replaced controller timer wouldnt adjust down
  - Dickson county jail. Readjusted timer on controller to lower the time the valve in open when fired
- Spray fields
  - Several of the spray heads that were reworked are getting hung in one position and not freely rotating.
  - Spray heads that have a pvc stand pipe need to be replaced with metal due to pipes not being rigid enough to allow the spray head to spin.
  - Aerator 2-2 has kicked the main breaker inside the shop. Will be addressed
  - Fence has multiple areas that needs to be repaired
  - Bush hogged some of the areas with weeds and thistles. Bush hogged all the sage grass.
- Reports
  - 2 Ecoli test will be run this quarter. During the first quarter I failed to send off an E.coli test. The state has been notified of this incident.
- Pumps
  - Vacuum pump at TN tool is ready for pickup.
  - Sewer pump #1 seals have been installed. Waiting for impeller.
  - Irrigation pump #2 at sewer plant still not operating at full capacity. (plan on pulling it when sewer pump is completed)
- Wastewater license
  - CED hours have been completed for Wastewater plant license.
  - Need 6 CED hours for my collections license.