

Wastewater Meeting Agenda

September 22, 2026

Sewer Issues:

- 213 Todd Street Replaced controller
- 105 Dunning Street. Replaced controller
- 3204 Vanleer Hwy Replaced controller
- DCSO readjusted controller. Timing was off
- 117 Todd Street readjusted controller timing and readjusted sensor tube
- CMS readjusted controller timing
- 305 Spencer alley. Replaced busted fiberglass lid with New Steel Lid

Sewer taps:

- Robertson street tap for the county will be next.

Sewer pumps:

- New volute for sewer pump number one has been ordered supposed to ship within a week of 9/14. Pump #1 will be operational after new parts are in.
- Sewer pump #2 will be removed for inspection after #1 is operational
- Irrigation pump #2 will be pulled for inspection wehn sewer pumps are complete

Trucks:

- Truck #2 will be in need of tires before winter.

Grants:

- Community Development Partners contact is out of the office for a while. She was looking into grants the city would be able to use beforehand. Would y'all like to contact them and see if there is anyone else we can use to continue looking. This will be for Sewer and General

Plant Expansion:

- Needs to be addressed again. During dry weather the sewer plant flow is running from 80,000-100,000 GPD. Our sewer plant design limit is 102,000 GPD. We cleared some property 5-7 acres roughly to add sprays to on the north side of the Sewer plant property. It will still need quite a bit of work to get remaining stumps removed
- INI will still be addressed going forward and will always be a issue with any sewer system.