Wastewater-Sewer Board Meeting Agenda

October 27, 2026

Sewer pumps:

● Country View market customer complaint of sewer smell
● 518 Lewis Lane Customer complaint. Sewer service clogged. Used drain can to blow out line
● Carwash Pump station. Pump 1 burned up. Was installed for 1 day.Replaced pump 1. Replaced Pump 2, cleaned filters and replaced 2 floats
● 3934 hwy 47 Cleaned filter on pump. Repaired Glue fitting inside tank

Sewer pumps:

● Sewer pump #1 is repaired. Delta Electric is repairing power supply line to the pump.

Spray Fields:

● All fields have been cut
● Multiple spots are in need of repairs
● Some Fence lines will need to be repaired from trees falling and animals running through