

Wastewater/Sewer Board Meeting Minutes
August 25,2026

Mayor and Council Present:

Garland Breeden, Melinda Miller, Ricky Pastor, Leah Green, Stevie Smith, Chris Deloach

Absent: Caleb Story

City Attorney Present: Kirk Vandivort

Sewer Manager Present: Chad Morrow

City Recorder Present: Shari Wright

Meeting Called to Order at 5:30pm by Mayor Garland Breeden.

- 117 Cedar view. Customer complaint. Low vacuum due to leak caused the tank to not fire. Manually emptied tank.
- 139 Lynn Lane. Controller malfunctioned
- 108 Lynn Lane. Replaced Fernco in tank
- 3155 Vanleer Hwy. Repaired Fernco in tank
- Luke Lane pump station. High level alarm. Replaced one of float cleaned filters on pumps
- 3411 Hwy 48. Repaired Fernco. Replaced Valve and controller
- 3155 Vanleer Hwy Fernco repair
- 3411 Hwy 48 N. replaced controller
- Charlotte Middle School. Debris hung under the valve. Manually opened tank cleared blockage
- 787 Spring Street. Replaced controller
- 108 Lynn Lane. Tank Full Replaced controller and valve
- 721 Spring Street. The controller hung open.
- 3368 Hwy 48. Cleaned pump filter adjusted Floats
- 3055 Vanleer Hwy replaced controller
- 106 Dunning St. Replaced valve and controller
- Line broke at the pharmacy During excavation of drainage ditch.
- 224 Park Circle. The Tank was full. Replaced valve and controller
- 108 Dunning Street. Manually triggered valve to reseal
- Dickson County Jail. Replaced controller. Staying open too long
- 124 Corlew Street. Removed valve cleared plastic cut out blockage
- 3499 Hwy 47. Rewired floats to run one pump. Cleaned filters on pumps. Waiting on floats to arrive from Adenus
- Rerouted service line from Johnas Pizza to keep it on the back side of the pharmacy's drainage ditch.
- 216 Park Circle West. Tank Full. Hose had split in it causing the controller and valve not to open properly. Replaced 5 ft of hose

Mayor Breeden motioned to adjourn the meeting and Chad Morrow seconds. Ayes: All

Approved:

Chad Morrow, Wastewater Operator

Mayor Garland Breeden

Date: _____