

SMOKE DETECTOR/CARBON MONOXIDE REQUIREMENTS

CERTIFICATE SHALL BE ISSUED UPON THE FOLLOWING CONDITIONS:

ALL PROTECTIVE DEVICES AND EQUIPMENT REQUIRED TO BE INSTALLED BY THE REGULATIONS WILL CONTINUE TO BE OPERATIONAL AS REQUIRED BY THE REGULATIONS

UCC 5:23-2.24(a)5

-
- ONE SMOKE DETECTOR ON EACH LEVEL, INCLUDING THE BASEMENT (IF APPLICABLE). A DETECTOR MUST BE WITHIN 10 FEET OF ANY BEDROOM ON ALL LEVELS
 - ONE CARBON MONOXIDE DETECTOR WITHIN 10 FEET OF ANY BEDROOM ON ALL LEVELS
 - BATTERY-OPERATED SMOKE DETECTORS – MUST BE TEN YEAR SEALED BATTERY-OPERATED SMOKE DETECTORS
 - HARDWIRED SMOKE DETECTORS MUST REMAIN HARDWIRED AND IF MORE THEN TEN YEARS OLD MUST BE REPLACED. **(DO NOT REPLACE HARDWIRED SMOKE DETECTORS WITH SEALED BATTERY-OPERATED SMOKE DETECTORS)**
-

FAILURE TO HAVE THE ABOVE IN PLACE WILL REQUIRE YOU TO MAKE ANOTHER APPOINTMENT AND SUBMIT A FEE OF \$35.00

ALL CANCELLATIONS MUST BE MADE IN WRITING 24 HOURS IN ADVANCE AND CAN BE E-MAILED TO: FIREDISTRICT3@OBF3.COM

ALL REINSPECTIONS/CANCELLATIONS HAVE TO BE DONE WITHIN 30 DAYS. ANY INSPECTION CONDUCTED AFTER 30 DAYS WILL REQUIRE FULL PAYMENT SCHEDULE AS LISTED ON APPLICATION