

 <p>DEE CRAMER HEATING COOLING SHEET METAL <i>Dedicated People. Delivering Quality.</i></p>	<p>Dee Cramer, Inc. Safety Management System</p>	Doc No:	TEMP HEAT	
		Initial Issue Date	10/21/2024	
		Revision Date:	Initial Version	
<p>Jobsite Temporary Heating Plan (Kerosene Heater)</p>		Revision No.	0	
		Next Review Date:	10/21/2025	
Preparation: Safety Director	Authority: President	Issuing Dept: Safety	Page:	Page 1 of 1

Purpose

The purpose of this program is to define the requirements for safely establishing a temporary jobsite heating plan.

Scope

This policy shall cover all temporary heating plans used on Dee Cramer, Inc. property or jobsites.

Key Responsibilities

Supervisors

- Shall ensure that all temporary heated areas are properly set-up and operated by competent personnel.
- Shall ensure pre-use inspections are performed prior to equipment use.

Employees

- Shall follow all aspects of this program.

Procedure for Safe Operational Use

- Enclose designated break area
 - Use of Fire Retardant Visqueen is required.
 - Dee Cramer Designated Break Area Entry / Exit signs will be posted at each entry to the break area.
- Kerosene 90,000 BTU Heater to be used
 - Place heater in location so that combustibles (anything capable of catching fire) are at least 25 feet away.
 - Inspect heater before every use.
 - Never move the heater while it is in use.
 - Ventilation is required when the heater is in use to maintain a safe atmosphere.
 - Never leave the heater running in an unoccupied space or unattended.
 - Heater has a safety shutoff device that will extinguish the flame if the unit is jarred or tipped over.
 - The smell of Kerosene gas is common when starting the device.
 - A class ABC fire extinguisher will be located within 25 feet of the heater.
- Fuel handling procedure
 - Always add fuel at the start of the shift.
 - Never add fuel while the heater is on or hot from operation.
 - Never add fuel in the break area, this will prevent fuel spills on the jobsite.
 - Store Kerosene fuel at least 20 feet from any building or property line in an approved canister.
 - Store Canister in labeled fireproof containment cabinet.
 - If Kerosene is spilled, clean it immediately and contact on site safety.