



Lead and Copper Analysis Report

Received

JUL 26 2021

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #: **2270000** City / Town: **SHIRLEY** **Shirley Water District**

PWS Name: **SHIRLEY WATER DISTRICT** PWS Class: COM NTNC TNC

Routine or Special Samples	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction	

SAMPLE NOTES – (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: **M-MA1118** Primary Lab Name: **NASHOBA ANALYTICAL, LLC** Subcontracted? (Y/N) **N**

Analyte	Action Level (mg/L)	Lab Method	MDL (mg/L)	Analysis Lab MA Cert.#	Analysis Lab Name
Lead:	0.015	EPA 200.9	0.001	M-MA1118	Nashoba Analytical, LLC
Copper:	1.3	EPA 200.7	0.004	M-MA1118	Nashoba Analytical, LLC

LAB SAMPLE NOTES

DEP Approved Sample Location (See DEP approved LCR plan for sampling locations)	Collection Date	LEAD		COPPER		Lab Sample ID#
		Result (mg/L)	Date Analyzed	Result (mg/L)	Date Analyzed	
1 3 APPLE ROCK WAY	7/13/2021	0.001	7/16/2021	0.044	7/16/2021	230106-1
2 11 APPLE ROCK WAY	7/13/2021	0.002	7/16/2021	0.13	7/16/2021	230106-2
3 6 LAYER ROAD	7/13/2021	ND	7/16/2021	0.12	7/16/2021	230106-3
4 28 CENTER ROAD	7/13/2021	ND	7/16/2021	0.213	7/16/2021	230106-4
5 148 CENTER ROAD	7/13/2021	0.001	7/16/2021	0.104	7/16/2021	230106-5
6 87 CLARK ROAD	7/13/2021	ND	7/16/2021	0.161	7/16/2021	230106-6
7 21 HARVARD ROAD	7/13/2021	0.001	7/16/2021	0.48	7/16/2021	230106-7
8 45 HARVARD ROAD	7/13/2021	0.001	7/16/2021	0.21	7/16/2021	230106-8
9 57 HARVARD ROAD	7/13/2021	0.002	7/16/2021	0.015	7/16/2021	230106-9
10 3 HASKELL STREET	7/13/2021	ND	7/16/2021	0.255	7/16/2021	230106-10
11 18 HAZEN ROAD	7/13/2021	ND	7/16/2021	0.103	7/16/2021	230106-11
12 23 LEOMINSTER ROAD	7/13/2021	0.003	7/16/2021	0.148	7/16/2021	230106-12
13 15 PAGE STREET	7/13/2021	ND	7/16/2021	0.014	7/16/2021	230106-13
14 19 PAGE STREET	7/13/2021	ND	7/16/2021	0.226	7/16/2021	230106-14
15 8 SOUTH STREET	7/13/2021	0.001	7/16/2021	0.205	7/16/2021	230106-15
16 15 VALLEY VIEW WAY	7/13/2021	ND	7/16/2021	0.102	7/16/2021	230106-16
17 22 VALLEY VIEW WAY	7/13/2021	ND	7/16/2021	ND	7/16/2021	230106-17
18						
19						
20						

Report SCHOOL RESULTS collected in accordance with 310 CMR 22.06B (7)(a)9 below. Do not use these school results in 90th percentile calculations.

1						
2						
3						
4						

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.


Primary Lab Director Signature: David L. Thwaitte

Date: 7-20-21

If not submitting these results electronically, mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

COM & NTNC Public Water Suppliers must submit Forms LCR-D or LCR-E with this form to the appropriate DEP Regional Office.

DEP REVIEW STATUS (Initial & Date)	Review Comments
<input type="checkbox"/> Accepted <input type="checkbox"/> Disapproved	



Lead and Copper Analysis Report

Received

AUG 02 2021

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #: **2270000** City / Town: **SHIRLEY**
 PWS Name: **SHIRLEY WATER DISTRICT** PWS Class: COM NTNC TNC
 Shirley Water District

Routine or Special Samples	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction	

SAMPLE NOTES – (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: **M-MA1118** Primary Lab Name: **NASHOBA ANALYTICAL, LLC** Subcontracted? (Y/N) **N**

Analyte	Action Level (mg/L)	Lab Method	MDL (mg/L)	Analysis Lab MA Cert.#	Analysis Lab Name
Lead:	0.015	EPA 200.9	0.001	M-MA1118	Nashoba Analytical, LLC
Copper:	1.3	EPA 200.7	0.004	M-MA1118	Nashoba Analytical, LLC

LAB SAMPLE NOTES

DEP Approved Sample Location (See DEP approved LCR plan for sampling locations)	Collection Date	LEAD		COPPER		Lab Sample ID#
		Result (mg/L)	Date Analyzed	Result (mg/L)	Date Analyzed	
1 21 CENTER ROAD	7/20/2021	ND	7/21/2021	0.121	7/21/2021	230497-1
2 10 HAZEN ROAD	7/20/2021	ND	7/21/2021	0.018	7/21/2021	230497-2
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Report SCHOOL RESULTS collected in accordance with 310 CMR 22.06B (7)(a)9 below. Do not use these school results in 90th percentile calculations.

1						
2						
3						
4						


I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature: David L. Knowlton
Date: 7-23-21

If not submitting these results electronically, mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

COM & NTNC Public Water Suppliers must submit Forms LCR-D or LCR-E with this form to the appropriate DEP Regional Office.

DEP REVIEW STATUS (Initial & Date)	Review Comments
<input type="checkbox"/> Accepted <input type="checkbox"/> Disapproved	



Massachusetts Department of Environmental Protection - Drinking Water Program **LCR-C**
Lead and Copper Analysis Report

Received

AUG 02 2021

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

PWS ID #: **2270000** City / Town: **SHIRLEY**
 PWS Name: **SHIRLEY WATER DISTRICT** PWS Class: **COM** **NTNC** **TNC**

Shirley Water District

Routine or Special Samples	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:	
		(1) Reason for Resubmission	(2) Collection Date of Original Sample
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction	
SAMPLE NOTES – (Such as, if a Manifold/Multiple sample, list the sources that were on-line during sample collection).			

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: **M-MA1118** Primary Lab Name: **NASHOBA ANALYTICAL, LLC** Subcontracted? (Y/N) **N**

Analyte	Action Level (mg/L)	Lab Method	MDL (mg/L)	Analysis Lab MA Cert.#	Analysis Lab Name
Lead:	0.015	EPA 200.9	0.001	M-MA1118	Nashoba Analytical, LLC
Copper:	1.3	EPA 200.7	0.004	M-MA1118	Nashoba Analytical, LLC

LAB SAMPLE NOTES

	DEP Approved Sample Location (See DEP approved LCR plan for sampling locations)	Collection Date	LEAD		COPPER		Lab Sample ID#
			Result (mg/L)	Date Analyzed	Result (mg/L)	Date Analyzed	
1	15 APPLE ROCK WAY	7/21/21	ND	7/22/21	0.170	7/22/21	230597
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

Report SCHOOL RESULTS collected in accordance with 310 CMR 22.06B (7)(a)9 below. Do not use these school results in 90th percentile calculations.

1							
2							
3							
4							

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Lab Director Signature:

Date: **7-23-21**

If not submitting these results electronically, mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

COM & NTNC Public Water Suppliers must submit Forms LCR-D or LCR-E with this form to the appropriate DEP Regional Office.

DEP REVIEW STATUS (Initial & Date)	Review Comments
<input type="checkbox"/> Accepted <input type="checkbox"/> Disapproved	