



El Paso County Emergency Services District #2

16001 Socorro Road | PO Box 265

Fabens, TX 79838

☎: (915) 765-5049 | **Fax:** (915) 765-5055

Website: www.epcountyesd2.org

✉: inspections@epcountyesd2.org

EL PASO COUNTY E.S.D. 2 - FIRE MARSHAL'S OFFICE

Fire Alarm Plan

Submittal Requirements

(2021 IFC-901.2)

Fire Alarm Systems installed within El Paso County ESD #2 territory shall meet all the requirements of the 2015 International Fire Code, local amendments, as well as all applicable NFPA Standards. All final systems testing, and inspections will be witnessed by the El Paso County ESD #2 Fire Marshal's Office.

The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

- ____ Permit Application
- ____ Current copy of license issued by The State of Texas Fire Marshal (1 copy)
- ____ System Designer
- ____ Contractor/Company
- ____ Installers
- ____ Submittal Packet (1 copy)
- ____ System Design Description
- ____ Manufacturer's Product Information Sheets of Listed Devices
- ____ Battery Calculations
- ____ Voltage Drop Calculations
- ____ Wiring Calculations
- ____ Riser Diagram
- ____ List of materials
- ____ Addressable Device List/Zone Legend

Fire Chief / Fire Marshal: Roger Esparza | **Assistant Fire Chief / Fire Marshal:** Joe Saucedo

Chief's / Fire Marshal's Assistants: Angie Hernandez | Rosie Edwards

Captain: Marco Herrera | **Lieutenant:** Juan Medina

Deputy Fire Marshals: Vicente Telas | Julian Carrasco

Revised:2026.06.16



El Paso County Emergency Services District #2

16001 Socorro Road | PO Box 265

Fabens, TX 79838

☎: (915) 765-5049 | **Fax:** (915) 765-5055

Website: www.epcountyesd2.org

✉: inspections@epcountyesd2.org

____ List Primary and Secondary Power

____ 1/8" Scaled Plans (3 copies)

____ Legend

____ North Arrow

____ Floor Plans Drawn that are free extraneous information

____ All Rooms Labeled for intended use

____ Separate Circuit Wiring (not conduit) Diagrams for Initiating and Indicating Circuits

____ Completed Devise-to-Devise wiring including End-Of-Line Resistors where applicable

____ Devise Address Numbers

____ System Designers Stamp with Wet Signature

____ Modification Permit (up to 10 devices)

____ Permit Application

____ Copy of Licenses

____ Plans 1/8" scale, 2 copies, stamped and wet signed

____ Legend showing existing, relocated or additional devices

____ Cut sheets for each new device or piece of equipment

Required Inspections

____ Pull stations

____ Smoke Detection (with smoke)

____ Heat Detection (with heat)

____ Audio Visual Devices

Fire Chief / Fire Marshal: Roger Esparza | **Assistant Fire Chief / Fire Marshal:** Joe Saucedo

Chief's / Fire Marshal's Assistants: Angie Hernandez | Rosie Edwards

Captain: Marco Herrera | **Lieutenant:** Juan Medina

Deputy Fire Marshals: Vicente Telas | Julian Carrasco

Revised:2026.06.16



El Paso County Emergency Services District #2

16001 Socorro Road | PO Box 265

Fabens, TX 79838

☎: (915) 765-5049 | **Fax:** (915) 765-5055

Website: www.epcountyesd2.org

✉: inspections@epcountyesd2.org

____ Visual Devices

____ Monitoring Capabilities

____ Other systems tied to system

Plans review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$71.00 per hour will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner.

INSTALLATION/MODIFICATION PERMIT AND AN APPROVED SET OF PLANS SHALL REMAIN AT THE JOB SITE AND PROVIDED TO INSPECTORS UPON REQUEST.

Fire Chief / Fire Marshal: Roger Esparza | **Assistant Fire Chief / Fire Marshal:** Joe Saucedo

Chief's / Fire Marshal's Assistants: Angie Hernandez | Rosie Edwards

Captain: Marco Herrera | **Lieutenant:** Juan Medina

Deputy Fire Marshals: Vicente Telas | Julian Carrasco

Revised:2026.06.16